LL97 Deep Energy Retrofit Studies

One Grand Central Place 1400 Broadway 501 7th Avenue 111 W 33rd Street

March 13th, 2024 REV 04 - Updated LL97 Limits

EMPIRE STATE

Table of Contents

- ESRT 2.0 Building Retrofit Goals
- Building Case Studies (OGCP, 1400, 501, 111)
 - Baseline Energy Modeling
 - ► ECM Phasing and Packaging
 - Energy and Carbon Emissions Results
 - ▶ Financial Analysis, LL97 Fines, and Recommendations
 - Capital Expenditure and 2023 Budget
- Lessons Learned
- Appendix

111 W 33rd Street 501 7th Avenue



One Grand Central Place

1400 Broadway

ESRT 2.0 Building Retrofit Goals

Building Case Studies (111, OGCP, 501,1400) Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget Lessons Learned Appendix



ESRT 2.0 - LL97 Deep Energy Retrofit Goals

- Evaluate the technical and economic potential to achieve carbon neutrality
- Define technical and economic needs to meet and exceed State and City targets and plans for 2024, 2030, 2035, 2050
- Evaluate the effects of different grid commitments
- Conduct a thorough technology review via pilots, building tests, energy modeling, site visits and vendor evaluations
- Analyze whole system approach based on energy models, economic assessment and supply side opportunities
- Utilize private know-how, leadership and public funding
- Utilize multi-stakeholder engagement which thoroughly explores the role of tenants to meet targets



EMPIRE STAT

Defining Net-Zero Carbon

ESRT's working definition of net-zero existing buildings is that by drastically reducing building operational emissions, partnering with a renewably sourced grid aligned with CLCPA, and offsetting residual emissions through clean energy generation and/or RECs through a transparent accounting and reporting process, net annual building operational carbon emissions are equal to zero.

By 2035, the ESRT portfolio will target net-zero carbon through an 80% operational carbon reduction - achieved through a combination of energy efficiency measures and a more renewably sourced grid - and a 20% offset with offsite clean energy generation and RECs.





Grid Projections: CLCPA Grid Scenario vs. Projected Grid Scenario

Static Grid - 2019 electricity GHG coefficient

Projected Grid - projected electricity GHG coefficients

CLCPA Grid - electricity GHG coefficients in alignment with the NYS Climate Act (CLCPA)



REALTY TRUST

6

Utility Electricity Greenhouse Gas Coefficient Projections

Grid Projections: LL97 Grid Emissions (2024-2034)

LL97 Grid - electricity GHG coefficients for 2024-2029 and 2030-2034 provided in LL97 of 2019 and 2022 proposed rules



Utility Electricity Greenhouse Gas Coefficient Projections

Year

EMPIRE STAT

7

One Grand Central Case Study

8

Baseline Energy Modeling

ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



One Grand Central Place - Current Building Systems

A mix of mostly air-cooled as well as limited water-cooled and chilled water systems. Heating is provided by district steam connected to radiators. 2021 Energy Grade: B/74

Cooling

- Self contained air cooled vertical AC units. Some newer units are VAV, most units are older and constant volume
- ▶ Water cooled units serving retail and floors 3, 4, 46 and 47 with numerous cooling towers and circulating systems. 50 year-old indoor cooling towers serve equally old units on 46 and 47.
- > Chilled water plants serving the lobby, multi-tenant corridors, and floors 48-55
- Central chiller plant & cooling towers
 - (1) 90-ton water cooled screw chiller serving the lobby (recently retrofit)
 - (1) 90-ton water cooled modular chiller as backup for the lobby
 - (1) 210-ton water cooled modular chiller serving floors 48-55 (recent installation)
 - ▶ (1) 400-ton cooling tower serving 48-55 chiller (recent installation)
 - > (1) 200-ton air cooled modular chiller serving multi-tenant corridors (due for replacement)
 - ▶ Numerous smaller condenser water systems at 3rd floor serving retail tenants, lobby chiller and 3rd and 4th floor tenant with varying ages and conditions.
- Utility steam
 - Space heat: cast iron radiators throughout, a small hot water loop serving parts of floors 48-55 and an air handler coil serving the Madison Ave concourse
 - Base building domestic hot water
 - Steam kettles in Pera's kitchen





2019 Energy Breakdown by Utility

Carbon Intensity vs. Energy Intensity

District Steam

- 56.1% of energy usage
- 43.7% of CO2e emissions
 Electricity
- 41.6% of energy usage
- ▶ 54.1% of CO₂e emissions

| 2019 OGCP Energy Use Index (EUI) | | | | | | | | |
|----------------------------------|------|--------------|--|--|--|--|--|--|
| Energy Source EUI Units | | | | | | | | |
| Electricity | 9.3 | kWh/SF/year | | | | | | |
| Natural Gas | 1.8 | kBtu/SF/year | | | | | | |
| District Steam | 42.7 | kBtu/SF/year | | | | | | |
| Total 76.0 kBtu/SF/year | | | | | | | | |



YTRUS

2019 CO2e Emissions Breakdown by Utility

Electricity - 256.0 tCO2e/GWh (Luthin) Steam - 153.3 tCO2e/GWh (LL97) Natural Gas - 181.21 tCO2e/GWh (LL97)



TATE

LTY TRUST

2019 Operational Cost Breakdown by Utility

Steam vs Electricity Operational Costs

District Steam

- ▶ 39.0% of operational costs
- 56.1% of energy usage

Electricity

- ▶ 60.4% of operational costs
- 41.6% of energy usage

Natural Gas only used in specific retail spaces



ALTY TRUS

OGCP Current Status for LL97 and 80x35 Challenge



Key Takeaways:

- Building meets 2024 Limit of 9,698 tCO2e/year
- Building meets 2030 Limit of 5,179 tCO2e/year
- 68% reduction is required to meet LL97 2035 target

 $24\%\ CO_2e$ Reduction from 2009 to 2019

- 43% due to electrical grid improvements
- ► 57% due to building improvements

OGCP Energy Breakdown by Major End Users

Steam Usage - 56%

Retail Tenants- 7.8%

Office Tenants - 24.3%

Base Building - 12.1%

- Tenant usage is based on Utilivisor Spreadsheet.
- Gerson Lehrman occupy 3rd and 4th Steam Usage. floor. 56.0%
- BK Restaurant has highest EUI 34 kBtu/SF



OGCP Electricity Breakdown by Major End Users

Office Tenants - 58.2%

- ▶ Ltg, Office Equip, IT Loads
- Tenant CW,CHW Systems?
- ► AHU Fans and DX cooling?

Base Building- 29.0%

- Lobby and BB CHW Systems
- ► CW, CHW, DHW pumps
- Elevators
- ▶ BB AHU, Ltg and Equipment

Retail Tenants- 12.8%

Tenant usage is based on Utilivisor Spreadsheet.



OGCP Energy Model: 2019 Energy Breakdown



OGCP Energy Model: 2019 CO2e Emissions Breakdown



One Grand Central Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



ECM Packages - Recommended Package is CO2 High

Four packages of ECMs were developed to optimize NPV and CO₂ reductions



CO₂ Light

BMS integration & controls optimizations, steam upgrades, infiltration mitigation, VFDs for lobby AHUs, regen drives for elevators, replace DC motors, tenant load improvements (lighting upgrades, plug load controls), conversion of CV systems to VAV



CO2 Mid Full Electrification: VRF + AWHPs

CO₂ Light + freight vestibules, VRF on L3-47 and roof-top AWHPs serving VAV reheats on L48-55.



CO2 High Full Electrification: VRF + AWHPs

CO2 Mid + vestibules at entrances, DHW electric heaters



CO2 Max Full Electrification: VRF

CO2 High + window retrofits, repair louver connections & VRF on L48-55 in lieu of AWHPs

REALTY TRUST

Carbon Reduction

ECM Phases & Implementation Timeline: CO₂ High

| ENERGY CONSERVATION MEASURES (ECMS) | | | | IMPLEMENTATION TIMELINE | | | | | | | | | | | |
|-------------------------------------|-------|---|------|-------------------------|------|------|------|------|------|------|------|------|------|------|------|
| Phase | Tag | ECM Description | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Phase 1 | CO001 | BMS Integration of VAV Boxes & Radiator Valves & ASHRAE Guideline 36 | 33% | 67% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |
| Phase 1 | SS001 | Steam Cycle and Pressure Optimization | 100% | | | | | | | | | | | | |
| Phase 1 | EN005 | Hoistway Vent Closure | 100% | | | | | | | | | | | | |
| Phase 2 | CO005 | Control Valves & VFDs for Lobby AHUs | | 100% | | | | | | | | | | | |
| Phase 2 | EN008 | Fix Seals on the Revolving Doors | | 100% | | | | | | | | | | | |
| Phase 2 | EN004 | Freight Vestibule | | 100% | | | | | | | | | | | |
| Phase 2 | EN002 | Vestibule at Street | | 100% | | | | | | | | | | | |
| Phase 2 | DW002 | Conversion of Steam Domestic Hot Water Heating to Electric | | 25% | 50% | 75% | 100% | | | | | | | | |
| Phase 2 | UL001 | Replace DC Motors (Fans, Pumps) with AC | | | | | 100% | | | | | | | | |
| Phase 2 | VT001 | Regenerative Drives & Destination Dispatch for Elevators | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 100% | 100% | 100% | | | |
| Phase 3 | EN001 | Radiant Barrier | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | | | |
| Phase 3 | SS003 | Radiator Pipe Insulation | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | | | |
| Phase 3 | TL002 | Lighting Upgrades & Controls | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | | | |
| Phase 3 | TL001 | Plug Load Control | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | | | |
| Phase 3 | EL001 | VRF Systems (ERV + DCV) for Office Tenants on Levels 3-47 | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | | | |
| Phase 4 | EL004 | Replace Corridor Air-Cooled Chiller with AWHP Serving Levels 48-55 | 0% | 0% | 20% | 40% | 60% | 80% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |

One Grand Central Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



OGCP ECM Package Comparison: Energy

Baseline: 2009

Proposed Energy Usage per Package Baseline: 2009



OGCP ECM Package Comparison: Energy Baseline: 2019

Proposed Energy Usage per Package Baseline: 2019



Projected CO₂ Emissions: <u>Static 2019</u> Grid Scenario



Proposed CO2e Emissions per Package (Static Grid Scenario)

Projected CO2 Emissions: Projected Grid Scenario



Proposed CO2e Emissions per Package (Projected Grid Scenario)

Projected CO₂ Emissions: <u>CLCPA</u> Grid Scenario



Proposed CO2e Emissions per Package (CLCPA Grid Scenario)

Projected Annual Carbon Emissions - LL97 Compliance

BAU does not achieve 2030 LL97 compliance; All packages are below 2024 and 2030 LL97 emissions limits



27

Projected Annual Carbon Emissions - Static 2019 Grid Scenario

No packages would meet **80% reduction** from 2009 baseline by **2035** without grid decarbonization; Only CO₂ High and above packages would meet **2030 LL97** limit; CO₂ Mid achieves limit by 2031



28

Projected Annual Carbon Emissions - Projected Grid Scenario

No packages would meet **80% reduction** from 2009 baseline by **2035**; CO₂ Mid and above packages meet **2035 LL97 limit**





Carbon Emissions Extended to 2040 - Projected Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2040; Projected fines for CO₂ Light, Mid, High & Max from 2035-2040¹: \$1,448,333 (Light), \$212,384 (Mid), \$168,780 (High), \$162,936 (Max)



30

REALTY TRUST

Total CO2 Emissions vs. Year - Projected Grid Scenario

Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the Projected grid scenario 1.

Projected Annual Carbon Emissions - CLCPA Grid Scenario

Only CO₂ Max and CO₂ High would meet 80% reduction from 2009 baseline by 2035; All packages except CO₂ Light would meet 2035 LL97 limit



Total CO2 Emissions vs. Year - CLCPA Target Grid Scenario

31

Carbon Emissions Extended to 2040 - CLCPA Grid Scenario

CO₂ Mid package meets **80% reduction** from 2009 baseline by **2036;** CO₂ Light <u>does not</u> meet **80% reduction** from 2009 baseline by **2040;** Projected fines for CO₂ Light, Mid, High & Max from 2035-2040¹: **\$645,489 (Light), \$64,168 (Mid), \$19,436 (High), \$15,945 (Max)**



Total CO2 Emissions vs. Year - CLCPA Target Grid Scenario

1. Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the CLCPA grid scenario

Percent Carbon Emissions Reductions - <u>All Grid Scenarios</u>

80x35 target based on reductions from 2009 baseline Reductions from 2019 baseline show impact of packages compared to current usage

STATIC GRID SCENARIO

| _ | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-----------------|
| CO2 MAX | -35.2% | -46.0% | -52.8% | - 60.7 % |
| CO2 HIGH | -33.9% | -45.1% | -51.9% | -60.1% |
| CO2 MID | -30.6% | -41.9% | -49.5% | -57.7% |
| CO2 LIGHT | -14.9% | -20.7% | -38.1% | -42.3% |

No packages would meet **80% reduction** from 2009 baseline by **2035** without grid decarbonization; Only CO₂ High and above packages would meet **2030 LL97** limit; CO₂ Mid achieves limit by 2031

PROJECTED GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -58.6% | -66.4% | -69.9% | -75.5% |
| CO2 HIGH | -57.7% | -65.8% | -69.2% | -75.1% |
| CO2 MID | -54.2% | -62.4% | -66.6% | -72.7% |
| CO2 LIGHT | -38.4% | -41.0% | -55.2% | -57.1% |

No packages would meet **80% reduction** from 2009 baseline by **2035**;

CO2 Mid and above packages meet 2035 LL97 limit

CLCPA TARGET GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -64.4% | -74.7% | -74.1% | -81.6% |
| CO2 HIGH | -63.5% | -74.3% | -73.4% | -81.3% |
| CO2 MID | -60.0% | -70.8% | -70.9% | -78.7% |
| CO2 LIGHT | -44.2% | -49.3% | -59.4% | -63.1% |

Only CO_2 Max and CO_2 High would meet **80%** reduction from 2009 baseline by **2035**; All packages except CO_2 Light would meet **2035** LL97 limit

33

One Grand Central Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



NPV, CO₂ Reductions and Simple Payback for all Packages Net Present Value for 2023-2035; CO₂ reduction based on CLCPA scenario



NPV vs. CO2 Reduction from 2023-2035 (CLCPA Target Grid Scenario)

NPV calculated with 6% real discount rate

Projected LL97 Fines From 2024-2034

No LL97 fines projected for the baseline for 2024-2029;

Fines possible from 2030-2034 for baseline if 2022 emissions limits are approved, though all packages offset the potential fines.

| | LL97 Fines From 2024-2034 | | | | | | | | |
|-----------------------|---|---|--------------------------------------|---|---|---|--|--|--|
| | LL97 of | 2019 Emission | s Limits ¹ | 2022 Proposed Emissions Limits ² | | | | | |
| Packages | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | Fine Avoidance From 2024- 2034 | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | Fine Avoidance From 2024- 2034 | | | |
| BAU (2019 Baseline) | \$0 | \$0 | - | \$0 | \$545,700 | - | | | |
| CO ₂ Light | \$0 | \$0 | \$0 | \$0 | \$0 | \$545,700 | | | |
| CO2 Mid | \$0 | \$0 | \$0 | \$0 | \$0 | \$545,700 | | | |
| CO2 High | \$0 | \$0 | \$0 | \$0 | \$0 | \$545,700 | | | |
| CO2 Max | \$0 | \$0 | \$0 | \$0 | \$0 | \$545,700 | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2024-2029 are based on GHG coefficients provided in LL97 of 2019.
- 4. Fine calculations for 2030-2034 are based on additional GHG coefficients provided in the proposed rules for LL97 released Oct. 2022.
Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario

Fines projected for the baseline and all packages except for CO₂ Max under currently published LL97 limits, though CO₂ Mid & High packages offset most of the fines;

Fines possible from 2035-2049 for baseline and all packages if 2022 emissions limits are approved, though CO₂ Mid, High & Max offset most of the potential fines.

| | Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario | | | | | | | |
|---------------------|---|--|---|---|--------------------------------------|---|--|--|
| | LL97 of | LL97 of 2019 Emissions Limits ¹ 2022 Proposed Emissions | | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | |
| BAU (2019 Baseline) | \$5,787,505 | - | \$322,502 | \$7,571,737 | - | \$751,722 | | |
| CO2 Light | \$3,560,363 | \$2,227,142 | \$189,938 | \$5,344,596 | \$2,227,142 | \$619,158 | | |
| CO2 Mid | \$119,319 | \$5,668,186 | \$0 | \$1,663,021 | \$5,908,717 | \$347,271 | | |
| CO2 High | \$2,078 | \$5,785,427 | \$O | \$1,223,469 | \$6,348,269 | \$303,169 | | |
| CO2 Max | \$0 | \$5,787,505 | \$ 0 | \$1,172,347 | \$6,399,391 | \$298,363 | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario

Fines projected for the baseline and CO₂ Light under currently published LL97 limits; packages CO₂ Mid, High, and Max offset all the fines.

Fines possible from 2035-2049 for baseline and all packages if 2022 emissions limits are approved, though CO₂ Mid, High, and Max packages offset most of the potential fines.

| | | Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario | | | | | | | | |
|---------------------|---|--|---|---|--------------------------------------|---|--|--|--|--|
| | LL97 or | LL97 of 2019 Emissions Limits ¹ 2022 Proposed Emissions L | | | | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | |
| BAU (2019 Baseline) | \$3,265,743 | - | \$172,808 | \$5,049,976 | - | \$602,028 | | | | |
| CO2 Light | \$1,672,187 | \$1,593,556 | \$77,854 | \$3,456,420 | \$1,593,556 | \$507,074 | | | | |
| CO2 Mid | \$O | \$3,265,743 | \$0 | \$417,784 | \$4,632,192 | \$233,980 | | | | |
| CO₂ High | \$0 | \$3,265,743 | \$0 | \$33,906 | \$5,016,070 | \$189,016 | | | | |
| CO2 Max | \$0 | \$3,265,743 | \$0 | \$23,817 | \$5,026,159 | \$186,008 | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Financial & Carbon Summary - Recommended Package is CO₂ High

| Meets 80x35 Target (CLCPA Grid, Y/N) | CO2 Light (N) | CO2 Mid (N) | CO2 High (Y) | CO2 Max (Y) |
|---|-----------------|----------------------------|-----------------|-----------------|
| Carbon Emissions in 2035 (CLCPA Grid) | 2,391 | 1,377 ^{12% de} | crease 1,213 | 1,194 |
| NPV (2023-2035) ¹ | (\$2,790,703) | \$1,387,275 | \$371,618 | (\$15,598,803) |
| NPV (Asset Life) ¹ | \$570,550 | \$7,058,693 | \$6,114,559 | (\$12,270,285) |
| Base Capital Cost ² | (\$127,064,053) | (\$131,484,932) | (\$131,484,932) | (\$127,337,862) |
| Incremental Capital Cost ² | (\$11,238,013) | (\$11,729,993) | (\$13,519,187) | (\$34,713,480) |
| Annual Energy Cost Savings ² | \$691,438 | \$1,296,856 6.4% in | \$1,379,914 | \$1,444,507 |
| Annual Repairs & Maintenance Savings | \$6,650 | \$1,950 | (\$16,250) | (\$9,950) |
| Incentives | \$1,095,382 | \$3,576,505 | \$3,580,040 | \$3,653,195 |
| Simple Payback | 14.5 | 6.3 | 7.3 | 21.7 |

CO2 Light Reduction - BMS integration & controls optimizations, steam upgrades, infiltration mitigation, VFDs for lobby AHUs, regen drives for elevators,

replace DC motors, tenant load improvements (lighting upgrades, plug load controls), conversion of CV systems to VAV

CO2 Mid Reduction - CO2 Light + freight vestibules, full electrification via VRF on L3-47 and roof-top AWHPs serving VAV reheats on L48-55.

CO2 High Reduction - CO2 Mid + vestibules at entrances, electrification of DHW

CO2 Max Reduction - CO2 High + window retrofits, repair louver connections & full electrification of L48-55 via VRF

Notes:

39

EMPIRE STATE

1. NPV calculated with 6% real discount rate

2. Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.

Financial Breakdown - Recommended Package is CO2 High

| | CO2 Light | CO2 Mid | CO2 High | CO2 Max |
|---|-----------------|-----------------|-----------------|-----------------|
| NPV (2023-2035) ¹ | (\$2,790,703) | \$1,387,275 | \$371,618 | (\$15,598,803) |
| NPV (Asset Life) ¹ | \$570,550 | \$7,058,693 | \$6,114,559 | (\$12,270,285) |
| Base Capital Cost ² | (\$127,064,053) | (\$131,484,932) | (\$131,484,932) | (\$127,337,862) |
| Base Building Infrastructure | (\$13,750,000) | (\$18,170,879) | (\$18,170,879) | (\$14,023,809) |
| > Tenant Fitout HVAC ³ | (\$113,314,053) | (\$113,314,053) | (\$113,314,053) | (\$113,314,053) |
| Incremental Capital Cost ² | (\$11,238,013) | (\$11,729,993) | (\$13,519,187) | (\$34,713,480) |
| Annual Energy Cost Savings ² | \$691,438 | \$1,296,856 | \$1,379,914 | \$1,444,507 |
| Annual Repairs & Maintenance Savings | \$6,650 | \$1,950 | (\$16,250) | (\$9,950) |
| Incentives | \$1,095,382 | \$3,576,505 | \$3,580,040 | \$3,653,195 |
| Simple Payback | 14.5 | 6.3 | 7.3 | 21.7 |

Notes:

1. NPV calculated with 6% real discount rate

2. Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.

3. Tenant fitout HVAC base capital costs include cost of new tenant VAV systems with electronic radiator valves, including new AHUs, and code minimum plug load controls

EMPIRE STATE

REALTY TRUST

40

Recommended Package - CO2 High

- Replace aged air-cooled chiller serving interior corridors with new air to water heat pump (AWHP)
 - AWHP installation provides heating for floors 48-55 during the winter when the corridor CHW system is not used
- Replace tenant cooling systems with VRF at every tenant fit out on floors 3-47
 - ▶ High heating load means it is critical to change heating from steam to heat pumps to meet targets by 2035
 - VRF systems are estimated to be the same cost as installation of the self-contained air-cooled vertical systems that have previously been installed in the building
- Install point of use domestic water heating in core restrooms at the time of cosmetic upgrades
 - Provides significant reduction in standby losses
- Improve upon efficiencies of existing steam system
 - Optimize steam cycle control and reduce pressure of steam distribution to reduce overheating from piping and oversized radiators
 - Replace thermostatic radiator valves with electronic control valves tied to the BMS to prevent simultaneous heating and cooling
- Convert existing constant volume lobby AHUs to operate with variable flow tied to the BMS
- Reduce lobby infiltration with the correction of leaky revolving doors and re-introduction of vestibules

41

One Grand Central Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



Annual Incremental Capital Cost per Package

Most of the capital expenditure occurs in the first 3 years to cover base building projects like controls & steam system optimizations, infiltration mitigation, electrification of DHW, & installation of AWHPs on the roof



Capital Cost (\$)

Annual Incremental Capital Cost vs. Base Cost per Package

Base costs include planned elevator modernization & DC conversion, code minimum plug load controls, replacement of aged roof-top AC chillers, required radiator valve replacements, & conversion to VAV systems



Total Capital Costs - Base Cost & Incremental

OGCP Next Steps - 2023 Projects

The recommended 2023 measures are focused on controls & envelope measures to upgrade central infrastructure and have a combined payback of ~12.5 yrs

| Project | 2023 Total Incremental Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|---|-------------------------------------|--------------------------------|---------------------------------------|--------------------------|
| BMS Integration of VAV Boxes & Radiator Valves & ASHRAE Guideline 36 ¹ | \$1,689,690 | \$400,000 | \$1,289,690 | \$37,268 |
| Steam Cycle and Pressure Optimization | \$756,865 | \$138,240 | \$618,625 | \$62,845 |
| Hoistway Vent Closure | \$29,869 | \$18,818 | \$11,052 | \$50,021 |
| Total LL97 Budget | \$2,476,425 | \$557,057 | \$1,919,367 | \$150,134 |

Note:

1. Capex and savings for BMS integration of VAV boxes and electronic radiator valves has been distributed over a 3-year period.

REALTY TRUS

1400 Broadway Case Study

Baseline Energy Modeling

ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



1400 Broadway - Current Building Systems

Two condenser water systems serve water-cooled air conditioners throughout the building. A few spaces still use air cooled units. Boilers make steam for heating in radiators. 2021 Energy Grade: B/83

- Condenser Water Systems
 - ▶ (1) 800-ton cooling tower with (3) 125-hp pumps
 - (3) 500-ton cooling towers with (3) 150-hp pumps
 - Many water-cooled AC units in good condition
- Air Cooled Systems
 - Some tenants have air cooled AC systems
- Steam System
 - (3) dual-fuel (natural gas & fuel oil #2) low pressure steam boilers serve cast iron radiators



47

2019 Energy Breakdown by Utility

Building Energy Utilization Index = 73.3 kBtu/SF/year

Energy Usage (mmBtu/year)

Electricity

- 60.0% of energy usage
- 61.8% of CO2e emissions
 Fuel Oil #2
- ► 31.0% of energy usage
- ► 31.6% of CO₂e emissions

Natural Gas

- 9.0% of energy usage
- 6.6% of CO2e emissions

| Energy Source | EUI | Units |
|---------------|------|--------------|
| Electricity | 12.9 | kWh/SF/year |
| Natural Gas | 6.6 | kBtu/SF/year |
| Fuel Oil | 22.7 | kBtu/SF/year |
| Total | 73.3 | kBtu/SF/year |



2019 Operational Cost Breakdown by Utility

Fuel Oil #2/Natural Gas vs Electricity Operational Costs

2019 utility operational cost = <u>\$2,262,689</u> Electricity

- ▶ 79.9% of operational costs
- 60.0% of energy usage
 Fuel Oil #2
- ▶ 15.3% of operational costs
- 31.0% of energy usage
 Natural Gas
- ▶ 4.8% of operational costs
- 9.0% of energy usage

Electricity - \$49.48 per MMBtu Natural Gas- \$19.67 per MMBtu Fuel Oil #2- \$18.37 per MMBtu



2019 CO2e Emissions Breakdown by Utility

Electricity

- ▶ 61.8% of CO₂e emissions
- ▶ 60.0% of energy usage

Fuel Oil #2

- ▶ 31.6% of CO₂e emissions
- 31.0% of energy usage
 Natural Gas
- ► 6.6% of CO₂e emissions
- 9.0% of energy usage

Electricity - 256.0 tCO₂e/GWh (Luthin) Fuel Oil #2 - 253.21 tCO₂e/GWh (LL97) Natural Gas - 181.22 tCO₂e/GWh (LL97)



1400 Broadway Current Status for LL97 and 80x35 Challenge

1400 Broadway CO2e Emissions Breakdown



Key Takeaways:

- Building meets 2024 Limit of 7,080 tCO2e/year
- Transition from Fuel Oil to Natural Gas provides immediate CO₂e emission reduction
- 6.8% reduction is required to meet LL97 2030 target of 3,765 tCO2e/year
- 71.2% reduction is required to meet LL97
 2035 target of 1,163 tCO2e/year
 - Building + grid improvements
- 31.0% CO2e Reduction from 2009 to 2019
 - 31.4% due to electrical grid improvements
 - Remaining due occupancy changes and/or building improvements

1400 Broadway Energy Breakdown by Major End Users

Data based on utility meters and Utilivisor Data

Retail Tenants. Base Building - 63.1% 4.8% Electricity - 23.2% ► Fossil Fuel - 39.9% Office Tenants_ Space Heating Office Tenants - 32.2% 32.2% 39.9% \blacktriangleright Retail Tenants- 4.8% \blacktriangleright

> Base Building 23.2%

1400 Broadway Electricity Breakdown by End Users



1400 Broadway Energy Model: 2019 Energy Breakdown

Analyzes major end-uses and highlight opportunities for improvement



1400 Broadway Energy Model: 2019 CO2e Emissions Breakdown

Analyzes major end-uses and highlight opportunities for improvement



1400 Broadway Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



ECM Packages - Recommended Package is CO2 High

Four packages of ECMs were developed to optimize NPV and CO₂ reductions



CO₂ Light No Electrification

BMS integration & controls optimizations, CW optimization, mitigate lobby infiltration, EMR cooling improvements, BOH lighting upgrades, DHW electric heaters, tenant load improvements (IT cooling, lighting upgrades, plug controls), conversion of CV systems to VAV, ERVs



CO2 Mid Partial Electrification: WWHPs

CO2 Light + WWHPs on C-L20; excludes DHW electric heaters



CO₂ High Full Electrification: VRF

CO2 Mid + VRF on C-L37, retail lighting improvements; excludes WWHPs



CO2 Max Full Electrification: VRF

CO₂ High + window improvements, retail BMS integration & controls, regen drives for elevators, DHW electric heaters





ALTY TRUST

ECM Phases & Implementation Timeline: CO₂ High

| | ENERGY CONSERVATION MEASURES (ECMS) | | | IMPLEMENTATION TIMELINE | | | | | | | | | | | |
|---------|-------------------------------------|--|------|-------------------------|------|------|------|------|------|-----------|------------------|------------------|------------------|-----------------|------|
| Phase | Tag | ECM Description | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Phase 1 | SS001 | Reduce Steam Pressure & Steam Cycling | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |
| Phase 1 | CO001 | BMS Integration of VAV Boxes & Radiator Valves & ASHRAE Guideline 36 | 25% | 50% | 75% | 100% | 100% | | | | | | | | |
| Phase 1 | CW001 | Optimize Condenser Water System | 100% | 100% | 100% | | | | | | | | | | |
| Phase 2 | EN001 | Mitigate Lobby Infiltration | 0% | 100% | | | | | | | | | | | |
| Phase 2 | LT001 | Common Area Lighting Upgrades | 0% | 100% | | | | | | | | | | | |
| Phase 2 | LT003 | Retail Lighting Improvements | 0% | 100% | | | | | | 100% | 100% lote: On | 100% ly 53% c | 100% of Tenan | 100% It Area | |
| Phase 2 | AS006 | Improve EMR cooling | 0% | 100% | | | | | | F 100% | Rolls by 2 | 2035 100% | | | 100% |
| Phase 4 | EL003 | Full Electrification: Full-Load Heating VRF Condenser Farm on Roof Serving Upper Floors Full-Load Heating VRF Systems Serving Lower Office Tenant Floors | 0% | 15% | 16% | 19% | 19% | 19% | 29% | 33% | 36% | 36% | 38% | 41% | 53% |
| Phase 4 | LT002 | Lighting Upgrades & Controls | 0% | 15% | 16% | 19% | 19% | 19% | 29% | 33% | 36% | 36% | 38% | 41% | 53% |
| Phase 4 | TL001 | Plug Load Control | 0% | 15% | 16% | 19% | 19% | 19% | 29% | 33% | 36% | 36% | 38% | 41% | 53% |
| Phase 4 | TL002 | Tenant IT Cooling | 0% | 15% | 16% | 19% | 19% | 19% | 29% | 33% | 36% | 36% | 38% | 41% | 53% |

1400 Broadway Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



1400 Broadway ECM Package Comparison: Energy

Baseline: 2009

Proposed Energy Usage per Package Baseline: 2009



1400 Broadway ECM Package Comparison: Energy Baseline: 2019

Proposed Energy Usage per Package Baseline: 2019



Projected CO₂ Emissions: <u>Static 2019</u> Grid Scenario



Proposed CO2e Emissions per Package (Static Grid Scenario)

Projected CO2 Emissions: Projected Grid Scenario



Proposed CO2e Emissions per Package (Projected Grid Scenario)

Projected CO2 Emissions: <u>CLCPA</u> Grid Scenario



Proposed CO2e Emissions per Package (CLCPA Grid Scenario)

Projected Annual Carbon Emissions - LL97 Compliance

BAU does not achieve 2030 LL97 compliance



65

FMPIRE

REALTY TRUST

Projected Annual Carbon Emissions - Static 2019 Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; No packages achieve 2030 LL97 compliance without grid decarbonization



REALTY TRUS

Projected Annual Carbon Emissions - Projected Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2035; No packages achieve 2035 LL97 compliance



67

7

REALTY TRUST

Carbon Emissions Extended to 2040 - Projected Grid Scenario

CO2 Light & Mid packages do not meet 80% reduction from 2009 baseline by 2040;

CO₂ High package meets **80% reduction** from 2009 baseline by **2039;** CO₂ Max package meets **80% reduction** from 2009 baseline by **2037;** Projected fines for CO₂ Light, Mid, High & Max from 2035-2040¹: **\$803,913 (Light), \$705,415 (Mid), \$289,881 (High), \$214,617 (Max)**



Total CO2 Emissions vs. Year - Projected Grid Scenario

1. Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the Projected grid scenario

Projected Annual Carbon Emissions - CLCPA Grid Scenario

Only CO₂ Max and CO₂ High packages would meet 80% reduction from 2009 baseline by 2035; Only CO₂ High and Max packages achieve 2035 LL97 compliance on time; CO₂ Mid complies by 2036



69

REALTY TRUST

Carbon Emissions Extended to 2040 - CLCPA Grid Scenario

CO2 Light package meets 80% reduction from 2009 baseline by 2037;

CO2 Mid package meets 80% reduction from 2009 baseline by 2036;

Projected fines for CO₂ Light, Mid, High, & Max from 2035-2040¹: \$173,171 (Light), \$143,050 (Mid), \$54,659 (High), \$38,491 (Max)



Total CO2 Emissions vs. Year - CLCPA Target Grid Scenario

1. Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the CLCPA grid scenario

Percent Carbon Emissions Reductions - <u>All Grid Scenarios</u>

80x35 target based on reductions from 2009 baseline

Reductions from 2019 baseline show impact of packages compared to current usage

STATIC GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -34.5% | -39.8% | -59.2% | -62.5% |
| CO2 HIGH | -32.1% | -36.1% | -57.8% | -60.2% |
| CO2 MID | -30.1% | -31.7% | -56.5% | -57.5% |
| CO2 LIGHT | -29.5% | -30.6% | -56.1% | -56.8% |

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; No packages achieve 2030 LL97 compliance without grid decarbonization

PROJECTED GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -59.4% | -62.9% | -74.7% | -76.9% |
| CO2 HIGH | -57.4% | -60.3% | -73.5% | -75.3% |
| CO2 MID | -55.2% | -55.7% | -72.1% | -72.4% |
| CO2 LIGHT | -54.6% | -54.6% | -71.7% | -71.7% |

No packages would meet 80% reduction from 2009 baseline by 2035;

No packages achieve 2035 LL97 compliance

CLCPA TARGET GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -65.5% | -72.3% | -78.5% | -82.7% |
| CO2 HIGH | -63.6% | -70.2% | -77.4% | -81.4% |
| CO2 MID | -61.4% | -65.4% | -76.0% | -78.5% |
| CO2 LIGHT | -60.8% | -64.3% | -75.6% | -77.8% |

Only CO_2 Max and CO_2 High packages would meet 80% reduction from 2009 baseline by 2035;

Only CO_2 High and Max packages achieve 2035 LL97 compliance on time; CO_2 Mid complies by 2036



1400 Broadway Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget


NPV, CO₂ Reductions and Simple Payback for all Packages Net Present Value for 2023-2035; CO₂ reduction based on CLCPA scenario



NPV vs. CO2 Reduction from 2023-2035 (CLCPA Target Grid Scenario)

Net Present Value (NPV)

NPV calculated with 6% real discount rate

Projected LL97 Fines From 2024-2034

No LL97 fines projected for the baseline or packages for 2024-2029

Fines possible from 2030-2034 for baseline if 2022 emissions limits are approved, though all packages offset the potential fines.

| | | | LL97 Fines From | 2024-2034 ו | | | | | | | | | |
|-----------------------|---|---|--------------------------------------|---|---|---|--|--|--|--|--|--|--|
| | LL97 of | 2019 Emission | s Limits ¹ | 2022 Proposed Emissions Limits ² | | | | | | | | | |
| Packages | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | Fine Avoidance From 2024- 2034 | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | Fine Avoidance From 2024- 2034 | | | | | | | |
| BAU (2019 Baseline) | \$0 | \$0 | - | \$0 | \$831,515 | - | | | | | | | |
| CO ₂ Light | \$0 | \$0 | \$0 | \$0 | \$0 | \$831,515 | | | | | | | |
| CO2 Mid | \$0 | \$0 \$0 | | \$0 | \$0 | \$831,515 | | | | | | | |
| CO2 High | \$0 | \$0 | \$0 | \$0 | \$0 | \$831,515 | | | | | | | |
| CO2 Max | \$0 | \$0 | \$0 | \$0 | \$0 | \$831,515 | | | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2024-2029 are based on GHG coefficients provided in LL97 of 2019.
- 4. Fine calculations for 2030-2034 are based on additional GHG coefficients provided in the proposed rules for LL97 released Oct. 2022.

Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario

Fines projected for baseline and all packages under currently published LL97 limits, though all packages offset most of the fines;

Fines possible from 2035-2049 for baseline and all packages if 2022 emissions limits are approved, though CO₂ Mid, High & Max packages offset most of the potential fines.

| | Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario | | | | | | | | | | |
|-----------------------|---|--------------------------------------|---|---|--------------------------------------|---|--|--|--|--|--|
| | LL97 of 2019 Emissions Limits ¹ 2022 Proposed Emissions | | | | | | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | | |
| BAU (2019 Baseline) | \$4,591,821 | - | \$237,130 | \$6,034,034 | - | \$548,948 | | | | | |
| CO ₂ Light | \$1,615,449 | \$2,976,371 | \$60,080 | \$3,057,663 | \$2,976,371 | \$371,898 | | | | | |
| CO2 Mid | \$1,359,296 | \$3,232,525 | \$42,518 | \$2,801,510 | \$3,232,525 | \$354,336 | | | | | |
| CO2 High | \$417,365 | \$4,174,456 | \$0 | \$1,661,275 | \$4,372,760 | \$273,572 | | | | | |
| CO2 Max | \$250,005 | \$4,341,816 | \$O | \$1,396,417 | \$4,637,617 | \$253,220 | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario

Fines projected for baseline and all packages except CO₂ Max under currently published LL97 limits, though all packages offset most of 2035-2049 for baseline and all packages if 2022 emissions limits are approved, though all packages offset most of the potential fines. the fines;

Fines possible from

| | Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario | | | | | | | | | | |
|---------------------|---|--------------------------------------|---|---|--------------------------------------|---|--|--|--|--|--|
| | LL97 of | 2019 Emissions | Limits ¹ | 2022 Proposed Emissions Limits ² | | | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | | |
| BAU (2019 Baseline) | \$1,844,704 | - | \$74,059 | \$3,286,918 | - | \$385,877 | | | | | |
| CO2 Light | \$178,450 | \$1,666,255 | \$0 | \$1,344,172 | \$1,942,746 | \$260,081 | | | | | |
| CO2 Mid | \$124,602 | \$1,720,103 | \$0 | \$1,152,888 | \$2,134,030 | \$242,156 | | | | | |
| CO2 High | \$17,867 | \$1,826,838 | \$O | \$321,069 | \$2,965,849 | \$159,458 | | | | | |
| CO2 Max | \$0 | \$1,844,704 | \$ 0 | \$170,686 | \$3,116,232 | \$144,826 | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Financial & Carbon Summary - Recommended Package is CO₂ High

| Meets 80x35 Target (CLCPA Grid, Y/N) | CO2 Light (N) | CO2 Mid (N) | CO2 High (Y) | CO2 Max (Y) |
|---|----------------|----------------|----------------------------|----------------|
| Carbon Emissions in 2035 (CLCPA Grid) | 1472 | 1427 | 1427 14% decrease 1230 | |
| NPV (2023-2035) ¹ | \$2,654,279 | \$794,510 | \$24,288 | (\$10,232,517) |
| NPV (Asset Life) ¹ | \$4,970,675 | \$2,012,857 | \$820,945 | (\$11,123,660) |
| Base Capital Cost ² | (\$47,423,169) | (\$47,423,169) | (\$47,423,169) | (\$47,423,169) |
| Incremental Capital Cost ² | (\$6,457,191) | (\$10,691,121) | (\$12,409,225) | (\$27,399,953) |
| Annual Energy Cost Savings ² | \$692,886 | \$708,926 | ^{rease} \$743,228 | \$827,344 |
| Annual Repairs & Maintenance Savings | \$0 | (\$3,150) | (\$6,150) | (\$6,150) |
| Incentives | \$1,763,851 | \$1,982,965 | \$3,382,760 | \$3,681,298 |
| Simple Payback | 6.8 | 12.3 | 12.2 | 28.9 |

CO2 Light Reduction -BMS integration & controls optimizations, CW optimization, mitigate lobby infiltration, EMR cooling improvements, BOH lighting upgrades, DHW electric heaters, tenant load improvements (IT cooling, lighting upgrades, plug controls), conversion of CV systems to VAV, ERVs

CO₂ Mid Reduction - CO₂ Light + WWHPs on C-L20; excludes DHW electric heaters

CO2 High Reduction - CO2 Mid + VRF on C-L37, retail lighting improvements; excludes WWHPs

CO2 Max Reduction - CO2 High + window improvements, retail BMS integration & controls, regen drives for elevators, DHW electric heaters

Notes:

1. NPV calculated with 6% real discount rate

2. Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.

77

Financial Breakdown - Recommended Package is CO₂ High

| | CO₂ Light | CO2 Mid CO2 High | | CO₂ Max | |
|---|----------------|------------------|----------------|----------------|--|
| NPV (2023-2035) ¹ | \$2,654,279 | \$794,510 | \$24,288 | (\$10,232,517) | |
| NPV (Asset Life) ¹ | \$4,970,675 | \$2,012,857 | \$820,945 | (\$11,123,660) | |
| Base Capital Cost ² | (\$47,423,169) | (\$47,423,169) | (\$47,423,169) | (\$47,423,169) | |
| > Base Building Infrastructure | (\$472,000) | (\$472,000) | (\$472,000) | (\$472,000) | |
| > Tenant Fitout HVAC ³ | (\$46,951,169) | (\$46,951,169) | (\$46,951,169) | (\$46,951,169) | |
| Incremental Capital Cost ² | (\$6,457,191) | (\$10,691,121) | (\$12,409,225) | (\$27,399,953) | |
| Annual Energy Cost Savings ² | \$692,886 | \$708,926 | \$743,228 | \$827,344 | |
| Annual Repairs & Maintenance Savings | \$0 | (\$3,150) | (\$6,150) | (\$6,150) | |
| Incentives | \$1,763,851 | \$1,982,965 | \$3,382,760 | \$3,681,298 | |
| Simple Payback | 6.8 | 12.3 | 12.2 | 28.9 | |

Notes:

1. NPV calculated with 6% real discount rate

 Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.

3. Tenant fitout HVAC base capital costs include cost of new tenant VAV systems with electronic radiator valves, excluding new AHUs, code minimum plug load controls, and planned CapEx for LL88 compliance

78

EMPIRE STATE

Recommended Package - CO2 High

- Replace water-cooled systems with air-cooled VRF at tenant fit out
 - Similar issues and drivers with floors 7-12 of 1333 Broadway:
 - Existing water-cooled systems are proving to be inefficient due to pumping energy
 - Roof area is inadequate to install a central hot water system covering the entire building, but is adequate to house VRF condensers for upper floors retaining windows with better views
 - Mechanical rooms are typically on the perimeter, VRF condensers should not significantly impact MER area compared to existing systems, but may impact number of windows. Louvers can be strategically placed where existing windows have limited light and views
- Controls
 - Immediately make improvements to optimize condenser water flow
 - Address uncontrolled heat (replace manual valves and TRVs with electronic)
 - Integrate tenant BMS with base building to ensure systems are operating efficiently



1400 Broadway Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



Annual Incremental Capital Cost per Package

Short term capital expenditure covers base building projects like controls, steam & CW optimizations, infiltration mitigation, BOH lighting upgrades, & DHW electric heaters. Longer term incremental costs align with tenant lease rolls



Annual Incremental Capital Cost vs. Base Cost per Package

Base costs include steam system maintenance & upgrades, LL88 lighting upgrades, code minimum plug load controls, required radiator control valve replacements, & installation of VAV systems at tenant fit out.



Total Capital Costs - Base Cost & Incremental

1400 Broadway Next Steps - 2023 Projects

The recommended 2023 measures are focused on BMS integration & controls optimizations that have a combined payback of ~1.0 yrs

| Project | 2023 Total Incremental Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|---|---|--------------------------------|---------------------------------------|-----------------------------|
| Reduce Steam Pressure & Steam Cycling (Includes Radiator Trap Audit & Replacements) | \$495,883 To Be Included in LL87 Compliance Budget | - | - | \$3,398 |
| BMS Integration of VAV Boxes & Radiator Valves & ASHRAE Guideline 361 | \$457,937 | \$192,283 | \$265,654 | \$76,349 |
| Optimize Condenser Water System | \$264,136 | \$166,406 | \$97,731 | \$296,380 |
| Total LL97 Budget | \$722,074 | \$358,689 | \$363,385 | \$376,127 |

Note:

1. Capex and savings for BMS integration of VAV boxes and electronic radiator valves has been distributed over a 4-year period.



501 7th Avenue Case Study

Baseline Energy Modeling

ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



501 7th Avenue - Current Building Systems

Water cooled AC units provide cooling and steam boilers provide heating to radiators 2021 Energy Grade: B/81

- Condenser water system
 - (2) 750-ton cooling towers
 - (3) 100-hp main circulating pumps
 - Smaller circulating pumps distributed throughout building for afterhours use
 - Many water-cooled AC units in good condition
- Boiler steam (fuel-oil to natural gas conversion underway)
 - Serves perimeter radiators
 - Boilers currently utilize fuel-oil, waiting on LL11 completion to finish natural gas conversion
- Other systems
 - Limited air-cooled units serving some retail and portions of floors 3 and 4



85

2019 Energy Breakdown by Utility

Building Energy Utilization Index = 69.7 kBtu/SF/year

Electricity

- ▶ 64.4% of energy usage
- 65.3% of CO2e emissionsFuel Oil #2
- ► 31.8% of energy usage
- 31.9% of CO2e emissions
 Natural Gas
- ► 3.8% of energy usage
- 2.7% of CO2e emissions

| Energy Source | EUI | Units |
|---------------|------|--------------|
| Electricity | 13.2 | kWh/SF/year |
| Natural Gas | 2.6 | kBtu/SF/year |
| Fuel Oil | 22.2 | kBtu/SF/year |
| Total | 69.7 | kBtu/SF/year |



2019 Operational Cost Breakdown by Utility

Fuel Oil #2/Natural Gas vs Electricity Operational Costs

2019 utility operational cost = <u>\$1,302,328</u> Electricity

- ▶ 84.5% of operational costs
- 64.4% of energy usageFuel Oil #2
- ▶ 14.5% of operational costs
- 31.8% of energy usage
 Natural Gas
- ▶ 1.0% of operational costs
- ► 3.8% of energy usage

Electricity - \$53.86 per MMBtu Fuel Oil #2 - \$18.70 per MMBtu Natural Gas - \$10.80 per MMBtu



2019 CO2e Emissions Breakdown by Utility

Electricity

- ▶ 65.3% of CO₂e emissions
- ▶ 64.4% of energy usage

Fuel Oil #2

- ► 31.9% of CO₂e emissions
- 31.8% of energy usage
 Natural Gas
- ► 2.7% of CO₂e emissions
- ► 3.8% of energy usage

Electricity - 256.0 tCO₂e/GWh (Luthin) Fuel Oil #2 - 253.21 tCO₂e/GWh (LL97) Natural Gas - 181.22 tCO₂e/GWh (LL97)



501 7th Ave. Current Status for LL97 and 80x35 Challenge

501 7th Ave. CO2e Emissions Breakdown



Key Takeaways for 2019 Adjusted Baseline:

- Building meets 2024 Limit of 3,885 tCO2e/year
- 4.0% reduction is required to meet LL97
 2030 target of 2,056 tCO2e/year
- 70.0% reduction is required to meet LL97
 2035 target of 637 tCO2e/year
 - Building + grid improvements

22.8% CO2e Reduction from 2009 to 2019

- ▶ 55.6% due to electrical grid improvements
- Remaining due occupancy changes and/or building improvements

FMPIRE

501 7th Ave. Energy Breakdown by Major End Users

Data based on utility meters and Utilivisor Data

Remaining Retail Chipotle_ Space Base Building - 49.3% Potbellies_ 2.6% 1.4% 4.6% Space Heating Electricity - 13.9% Remaining Office_ **Fossil Fuel** Space 31.6% Fossil Fuel - 35.4% 10.4% Office Tenants - 42.1% Carolina Herrera Carolina Herrera - 22.6 kWh/SE Ltd 7.4% NYS Office of Addiction Services -12.5 kWh/SF PVH Corp - 8.00 kWh/SF NYS Office of Addiction Retail Tenants- 8.6% Services 4.1% Potbellies EUI = 33.6 kWh/SF (179) DHW/Retail kBtu/SF) Fossil Fuel 3.8% Chipotle EUI = 37.3 kWh/SF (198) PVH Corp_ **Base Building** 20.2% kBtu/SF) Electricity

13.9%

501 7th Ave <u>Electricity</u> Breakdown by Major End Users



501 7th Ave. Energy Model: 2019 Energy Breakdown

Analyzes major end-uses and highlight opportunities for improvement

- ▶ Office Tenants account for ~45%
- ▶ Space Heating accounts for 30.9%
- Retail Tenants accounts for ~9% of total energy usage (only 5% of square footage)
- Base building accounts for ~15% of total energy usage
 - Optimized condenser water controls



501 7th Ave. Energy Model: 2019 CO2e Emissions Breakdown

Analyzes major end-uses and highlight opportunities for improvement



501 7th Avenue Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



ECM Packages - Recommended Package is CO₂ Mid

Four packages of ECMs were developed to optimize NPV and CO₂ reductions



Carbon Reduction

steam piping insulation

ALTY TRUS

ECM Phases & Implementation Timeline: CO2 Mid

| | ENERGY CONSERVATION MEASURES (ECMS) | | | IMPLEMENTATION TIMELINE | | | | | | | | | | | |
|---------|-------------------------------------|---|------|-------------------------|------|------|------|------|------|------|------|------|------|------|------|
| Phase | Tag | ECM Description | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Phase 1 | SS001 | Reduce Steam Pressure and Steam Cycling with Trap audit and replacement as necessary | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |
| Phase 1 | CO001 | DDC VAV Boxes and Electronic Radiator Valves & ASHRAE 36 | 25% | 50% | 75% | 100% | 100% | | | | | | | | |
| Phase 1 | CO002 | Tie-In VAV Diffuser Systems to BMS + Electronic Radiator Valves | 25% | 50% | 75% | 100% | 100% | | | | | | | | |
| Phase 1 | CW001 | Optimize Condenser Water System | 100% | 100% | | | | | | | | | | | |
| Phase 2 | AS005 | Improve EMR Cooling | 0% | 100% | | | | | | | | | | | |
| Phase 2 | EN003 | Hoistway Smoke Vent Closure | 0% | 100% | | | | | | | | | | | |
| Phase 2 | EN001 | Mitigate Lobby Infiltration | 0% | 100% | | | | | | | | | | | |
| Phase 2 | LT001 | Common Area Lighting Upgrades | 0% | 100% | | | | | | | | | | | |
| Phase 2 | AS003 | Energy Recovery Ventilators for Office Tenant Floors | 0% | 100% | | | | | | | | | | | |
| Phase 3 | EL001 | Distributed Water-Water Heat Pumps Connected to Existing Condenser Water System + VAV Reheat on Lower Office Floors (2-4) | 33% | 67% | 100% | 100% | | | | | | | | | |
| Phase 4 | AS002 | Convert CV & VAV Diffuser Systems to VAV Systems at Tenant Lease Roll | 17% | 19% | 21% | 38% | 39% | 92% | 99% | 99% | 99% | 100% | 100% | | |
| Phase 4 | LT002 | Lighting Upgrades & Controls | 17% | 19% | 21% | 38% | 39% | 92% | 99% | 99% | 99% | 100% | 100% | | |
| Phase 4 | TL001 | Plug Load Controls | 17% | 19% | 21% | 38% | 39% | 92% | 99% | 99% | 99% | 100% | 100% | | |
| Phase 4 | TL002 | Tenant IT Cooling | 17% | 19% | 21% | 38% | 39% | 92% | 99% | 99% | 99% | 100% | 100% | | |

501 7th Avenue Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



501 7th Ave. ECM Package Comparison: Energy Baseline: 2009



501 7th Ave. ECM Package Comparison: Energy Baseline: 2019



Proposed Energy Usage per Package

Projected CO₂ Emissions: <u>Static 2019</u> Grid Scenario



Proposed CO2e Emissions per Package (Static Grid Scenario)

Projected CO2 Emissions: Projected Grid Scenario



Proposed CO2e Emissions per Package (Projected Grid Scenario)

Projected CO₂ Emissions: <u>CLCPA</u> Grid Scenario



Proposed CO2e Emissions per Package (CLCPA Grid Scenario)

Projected Annual Carbon Emissions - LL97 Compliance

BAU does not achieve 2030 LL97 compliance



FMPIRE

Projected Annual Carbon Emissions - Static 2019 Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; No packages would meet 2035 LL97 limit without grid decarbonization



104

Projected Annual Carbon Emissions - Projected Grid Scenario

Only CO₂ Max package would meet 80% reduction from 2009 baseline by 2035; CO₂ High and Max packages achieve 2035 LL97 compliance



Carbon Emissions Extended to 2040 - Projected Grid Scenario

CO₂ Light, Mid, & High packages do not meet **80% reduction** from 2009 baseline by **2040;** Projected fines for CO₂ Light, Mid, High & Max from 2035-2040: **\$397,072 (Light), \$311,148 (Mid), \$86,735 (High), \$40,290 (Max)**



1. Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the Projected grid scenario

Projected Annual Carbon Emissions - CLCPA Grid Scenario

Only CO₂ High & Max packages would meet 80% reduction from 2009 baseline by 2035; CO₂ Mid and above packages achieve 2035 LL97 compliance



Carbon Emissions Extended to 2040 - CLCPA Grid Scenario

CO₂ Mid package meets 80% reduction from 2009 baseline by 2039; Projected fines for CO₂ Light & Mid respectively from 2035-2040¹: \$73,863 (Light). \$58,735 (Mid)



Total CO2 Emissions vs. Year - CLCPA Target Grid Scenario

Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the CLCPA grid scenario 1.
Percent Carbon Emissions Reductions - <u>All Grid Scenarios</u>

80x35 target based on reductions from 2009 baseline Reductions from 2019 baseline show impact of packages compared to current usage

STATIC GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -49.1% | -49.2% | -62.8% | -62.9% |
| CO2 HIGH | -40.6% | -40.7% | -56.6% | -56.7% |
| CO2 MID | -32.1% | -32.2% | -50.4% | -50.4% |
| CO2 LIGHT | -29.8% | -29.8% | -48.7% | -48.7% |

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; No packages would meet 2035 LL97 limit without grid decarbonization

PROJECTED GRID SCENARIO

| _ | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -74.5% | -74.2% | -81.4% | -81.1% |
| CO2 HIGH | -66.6% | -66.2% | -75.6% | -75.3% |
| CO2 MID | -56.0% | -55.6% | -67.8% | -67.6% |
| CO2 LIGHT | -53.5% | -53.2% | -66.1% | -65.8% |

Only CO_2 Max package would meet 80% reduction from 2009 baseline by 2035; CO_2 High and Max packages achieve 2035 LL97 compliance

CLCPA TARGET GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -80.7% | -84.3% | -85.9% | -88.5% |
| CO2 HIGH | -73.0% | -76.6% | -80.3% | -82.9% |
| CO2 MID | -61.8% | -65.1% | -72.1% | -74.5% |
| CO2 LIGHT | -59.4% | -62.7% | -70.3% | -72.7% |

Only CO₂ High & Max packages would meet 80% reduction from 2009 baseline by 2035;

 $\rm CO_2$ Mid and above packages achieve 2035 LL97 compliance

109



501 7th Avenue Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



NPV, CO₂ Reductions and Simple Payback for all Packages Net Present Value for 2023-2035; CO₂ reduction based on CLCPA scenario



EMPIRE STATE

REALTY TRUST

NPV vs. CO2 Reduction from 2023-2035 (CLCPA Target Grid Scenario)

NPV calculated with 6% real discount rate

Projected LL97 Fines From 2024-2034

No LL97 fines projected for the baseline for 2024-2029

Fines possible from 2030-2034 for baseline if 2022 emissions limits are approved, though all packages offset the potential fines.

| | LL97 Fines From 2024-2034 | | | | | | | | | | |
|-----------------------|---|---|---|---|-----------|-----------|--|--|--|--|--|
| | LL97 of | 2019 Emissions | s Limits ¹ | 2022 Proposed Emissions Limits ² | | | | | | | |
| Packages | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | l Fine 2030- 34 ⁴ From 2024- 2034 Total Fine From 2024- 2029 ³ Total Fine From 2030- 2034 ⁴ | | | | | | | | |
| BAU (2019 Baseline) | \$0 | \$0 | - | \$0 | \$366,935 | - | | | | | |
| CO ₂ Light | \$0 | \$0 | \$0 | \$0 | \$0 | \$366,935 | | | | | |
| CO2 Mid | \$0 | \$0 | \$0 | \$0 | \$0 | \$366,935 | | | | | |
| CO2 High | \$0 | \$0 | \$0 | \$0 | \$0 | \$366,935 | | | | | |
| CO2 Max | \$0 | \$0 | \$0 | \$0 | \$0 | \$366,935 | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2024-2029 are based on GHG coefficients provided in LL97 of 2019.
- 4. Fine calculations for 2030-2034 are based on additional GHG coefficients provided in the proposed rules for LL97 released Oct. 2022.



Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario

Fines projected for baseline and all packages except for CO₂ Max under currently published LL97 limits, though all packages offset most of the fines;

Fines possible from 2035-2049 for baseline and all packages if 2022 emissions limits are approved, though CO₂ Mid, High & Max offset most of the potential fines.

| | Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario | | | | | | | | | | |
|---------------------|---|--------------------------------------|---|---|--------------------------------------|---|--|--|--|--|--|
| | LL97 of | 2019 Emissions | Limits ¹ | 2022 Prop | osed Emissions | Limits ² | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | | |
| BAU (2019 Baseline) | \$2,291,419 | - | \$114,341 | \$3,022,980 | - | \$285,079 | | | | | |
| CO2 Light | \$980,167 | \$1,311,252 | \$39,673 | \$1,711,728 | \$1,311,252 | \$210,411 | | | | | |
| CO2 Mid | \$764,377 | \$1,527,042 | \$25,227 | \$1,495,938 | \$1,527,042 | \$195,965 | | | | | |
| CO2 High | \$86,451 | \$2,204,968 | \$0 | \$597,464 | \$2,425,516 | \$126,386 | | | | | |
| CO2 Max | \$0 | \$2,291,419 | \$ 0 | \$139,375 | \$2,883,605 | \$80,843 | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario

Fines projected for the baseline, CO₂ Light and Mid under currently published LL97 limits, though packages offset most of the fines;

Fines possible from 2035-2049 for the baseline, CO₂ Light and Mid if 2022 emissions limits are approved, though all packages offset most of the potential fines

| | Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario | | | | | | | | | | |
|-----------------------|---|--------------------------------------|---|---|---|---|--|--|--|--|--|
| | LL97 or | f 2019 Emissions | Limits ¹ | 2022 Proj | 2022 Proposed Emissions Limits ² | | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | | |
| BAU (2019 Baseline) | \$761,581 | - | \$23,528 | \$1,493,142 | - | \$194,266 | | | | | |
| CO ₂ Light | \$124,981 | \$636,600 | \$0 | \$773,620 | \$719,522 | \$149,733 | | | | | |
| CO2 Mid | \$70,619 | \$690,963 | \$0 | \$615,334 | \$877,808 | \$135,144 | | | | | |
| CO₂ High | \$0 | \$761,581 | \$0 | \$0 | \$1,493,142 | \$60,036 | | | | | |
| CO2 Max | \$0 | \$761,581 | \$0 | \$0 | \$1,493,142 | \$16,055 | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Financial & Carbon Summary - Recommended Package is CO2 Mid

| Meets 80x35 Target (CLCPA Grid, Y/N) | CO2 Light (N) | CO2 Mid (N) | CO2 High (Y) | CO2 Max (Y) |
|---|----------------|----------------|----------------|----------------|
| Carbon Emissions in 2035 (CLCPA Grid) | 829 | decrease 775 | 519 | 348 |
| NPV (2023-2035) ¹ | \$171,748 | (\$676,270) | (\$8,643,125) | (\$16,470,143) |
| NPV (Asset Life) ¹ | \$1,491,953 | \$618,221 | (\$8,279,746) | (\$17,313,245) |
| Base Capital Cost ² | (\$45,645,813) | (\$45,645,813) | (\$46,128,933) | (\$46,128,933) |
| Incremental Capital Cost ² | (\$5,484,359) | (\$6,748,860) | (\$16,634,033) | (\$27,217,779) |
| Annual Energy Cost Savings ² | \$386,055 | \$397,736 | \$396,886 | \$442,158 |
| Annual Repairs & Maintenance Savings | \$0 | \$0 | \$0 | \$0 |
| Incentives | \$1,216,360 | \$1,281,481 | \$1,555,535 | \$1,980,363 |
| Simple Payback | 11.1 | 13.7 | 38.0 | 57.1 |

CO₂ Light Reduction BMS integration & controls improvements, CW optimization, infiltration mitigation, tenant load improvements (lighting, plug loads, IT cooling), conversion of CV systems to VAV, ERVs

CO2 Mid Reduction CO2 Light + distributed WWHPs on L2-4, EMR cooling improvements

CO₂ High Reduction CO₂ Mid + beneficial electrification via centralized AWHPs on roof, electrical switchgear room temp control, DHW electric heaters, retail lighting improvements, AFMS & DCV, radiant barriers, steam piping insulation

CO2 Max Reduction - CO2 High + increased capacity AWHPs for full load heating of office and retail, TX ERV, integration of retail systems on BMS & lighting upgrades, window retrofits, regen drives for elevators 115

Notes:

1. NPV calculated with 6% real discount rate

2. Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.



Financial Breakdown - Recommended Package is CO2 Mid

| | CO2 Light | CO2 Mid | CO2 High | CO2 Max | |
|---|----------------|-------------------------------|----------------|----------------|--|
| NPV (2023-2035) ¹ | \$171,748 | (\$676,270) | (\$8,643,125) | (\$16,470,143) | |
| NPV (Asset Life) ¹ | \$1,491,953 | \$618,221 | (\$8,279,746) | (\$17,313,245) | |
| Base Capital Cost ² | (\$45,645,813) | (\$45,645,813) | (\$46,128,933) | (\$46,128,933) | |
| Base Building Infrastructure | (\$182,000) | (\$182,000) | (\$182,000) | (\$182,000) | |
| > Tenant Fitout HVAC ³ | (\$45,463,813) | (\$45,463,813) (\$45,946,933) | | (\$45,946,933) | |
| Incremental Capital Cost ² | (\$5,484,359) | (\$6,748,860) | (\$16,634,033) | (\$27,217,779) | |
| Annual Energy Cost Savings ² | \$386,055 | \$397,736 | \$396,886 | \$442,158 | |
| Annual Repairs & Maintenance Savings | \$0 | \$0 | \$0 | \$0 | |
| Incentives | \$1,216,360 | \$1,281,481 | \$1,555,535 | \$1,980,363 | |
| Simple Payback | 11.1 | 13.7 | 38.0 | 57.1 | |

Notes:

1. NPV calculated with 6% real discount rate

 Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.

3. Tenant fitout HVAC base capital costs include cost of new tenant VAV systems with electronic radiator valves, excluding new AHUs, code minimum plug load controls, and CO₂ sensors for CO₂ High and Max packages

116

EMPIRE STATE

Recommended Package - CO2 Mid

- Near term installation of water to water heat pumps on 3 lower floors to provide heating for anticipated full floor fit outs in the next 2-3 years
 - > Waste heat from cooling loads elsewhere in the building allows for heating electrification
 - Taking advantage of high server room and switchgear loads which are otherwise rejected to atmosphere in winter
- Immediate installation of ERVs
 - Existing mechanical rooms have plenty of space for ERVs which provide immediate heating and cooling savings, pipe freeze protection, continuous demand reduction, and improved humidity control
- Controls
 - Immediately link base building and extensive tenant BMS to allow energy efficient coordination of control of AHUs and VAV boxes & radiators to prevent simultaneous heating and cooling
- While there is currently no business case to install air to water heat pumps for additional heating electrification, we recommend re-evaluating the business case in the future as the market changes
 - Sufficient roof space available for future installation of AWHPs

501 7th Avenue Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



Annual Incremental Capital Cost per Package

Most of the capital expenditure for all packages occurs in the first 2 years to cover base building projects, including AWHP installation for CO₂ High & Max. Incremental costs align with tenant lease roll schedules.



Annual Incremental Capital Cost vs. Base Cost per Package

Base costs include steam system maintenance & upgrades, conversion code minimum plug load controls, required radiator control valve replacements, & installation of VAV systems & CO₂ sensors at tenant fit out.



Total Capital Costs - Base Cost & Incremental

501 7th Street Next Steps - 2023 Projects

The recommended 2023 measures are focused on BMS integration & controls optimizations that have a combined payback of ~7.0 yrs

| Project | 2023 Total Incremental Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|--|--|--------------------------------|---------------------------------------|-----------------------------|
| Reduce Steam Pressure and Steam Cycling with Trap audit and replacement as necessary | \$191,209 To Be Included in LL87 Compliance Budget | - | - | \$2,405 |
| DDC VAV Boxes & VAV Diffusers and Electronic Radiator Valves & ASHRAE 361 | \$464,670 | \$139,401 | \$325,269 | \$38,428 |
| Optimize Condenser Water System | \$728,161 | \$209,497 | \$518,664 | \$82,108 |
| Total LL97 Budget | \$1,192,831 | \$348,898 | \$843,933 | \$122,940 |

Note:

1. Capex and savings for BMS integration of VAV boxes and electronic radiator valves has been distributed over a 4-year period.



REALTY TRUST

111 W 33rd Street Case Study

Baseline Energy Modeling

ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



111 W 33rd Street - Current Building Systems

Chiller plant provides cooling, district steam used to generate <u>hot water</u> for perimeter induction units 2021 Energy Grade: B/82

- Central chiller plant & cooling towers
 - (1) 1200-ton magnetic-bearing centrifugal SMARDT water-cooled chiller installed in 2017. Chiller has (4) compressors, largest compressors are ~357 tons
 - (1) 1300-ton steam turbine centrifugal YORK chiller installed in 1991; intended for redundancy but not operational
 - (3) cell 1800-ton total base building cooling tower installed in 1995
 - (3) cell 750-ton total tenant cooling tower installed in 2014. Tenant condenser water system serves IT units, 2 office AHUs, and retail
- Utility steam
 - Serves heating coils in the AHUs
 - Used to generate heating hot water for secondary dual temperature system
- Secondary dual temperature system
 - (5) zoned heat exchangers (1 standby) installed in 1995 generate chilled or hot water to perimeter induction units



123

2019 Energy Breakdown by Utility

Building Energy Utilization Index = 48.3 kBtu/SF/year

Electricity

- 83.6% of energy usage
- 89.5% of CO2e emissions
 District Steam
- 16.4% of energy usage
- ▶ 10.5% of CO₂e emissions

| Energy Source | EUI | Units |
|---------------|------|--------------|
| Electricity | 11.8 | kWh/SF/year |
| Steam | 7.9 | kBtu/SF/year |
| Total | 48.3 | kBtu/SF/year |





2019 Operational Cost Breakdown by Utility

District Steam vs Electricity Operational Costs

2019 utility operational cost = <u>\$1,737,685</u> Electricity

- ▶ 84.8% of operational costs
- 83.6% of energy usage

District Steam

- ▶ 15.2% of operational costs
- 16.4% of energy usage





2019 CO2e Emissions Breakdown by Utility

District steam has slightly lower associated emissions than electricity

Electricity

- ▶ 89.5% of CO₂e emissions
- 83.6% of energy usage

District Steam

- 10.5% of CO2e emissions
- 16.4% of energy usage

Electricity - 256.0 tCO₂e/GWh (Luthin) Steam - 153.3 tCO₂e/GWh (LL97)



2019 CO2e Emissions Breakdown

111 W 33rd St. Current Status for LL97 and 80x35 Challenge



Key Takeaways:

 Building meets 2024 Limit of 7,023 tCO2e/year

- Building meets 2030 Limit of 3,624 tCO2e/year
- 58.7% reduction is required to meet LL97 2035 target
 - Building + grid improvements

46.1% CO2e Reduction from 2009 to 2019

- 23% due to switch from steam to electric chillers
- ▶ 26% due to electrical grid improvements
- Remaining due occupancy changes and/or building improvements EMPIRE ST

111 W 33rd St. Energy Breakdown by Major End Users

Data based on utility meters and Utilivisor



111 W 33rd St. <u>Electricity</u> Breakdown by Major End Users

Base Building- 35.9%

Retail Tenants - 35.4%

Office Tenants - 28.8%

 Retail and Office tenant usage is based on Utilivisor Spreadsheet.



111 W 33rd St. Energy Model: 2019 Energy Breakdown

Analyzes major end-uses and highlight opportunities for improvement

- Retail Tenants accounts for ~29% of total energy usage (only 10% of square footage)
 - High lighting power density
 - ▶ 24/7 lighting, HVAC
 - Refrigeration equipment (Target)
- ▶ Office Tenants account for ~32.5%
 - Potential for plug load controls
 - Potential LPD reduction to 0.6 W/SF
 - ► IT Loads improvements
- Steam Heating accounts for 16.5%
 - Improved HVAC Controls
 - Heating electrification
- Distribution energy (Fans + Pumps) account for 10.5%
 - Improved CHW/CW pump controls
 - Optimized BMS and ASHRAE Guideline 36 Sequence



ALTY TRUST

111 W 33rd St. Energy Model: 2019 CO2e Emissions Breakdown

Analyzes major end-uses and highlight opportunities for improvement

DHW 2.7% Retail Tenants accounts for ~31% of total CO₂e Steam Usage. Office Light 10.6% 14.7% emissions (only 10% of square footage) Elevator Office Tenants account for ~35% 3.0% Base Building accounts for ~34% Office Fans_ 7.1% Steam Heating accounts for 10.6% CHW-CW Pumps_ Distribution energy (pumps + fans) 11.3% 4.2% Office Equip 20.2% Cooling Towers_ 0.3% Office Cool 6.2% **Retail Flec Heat** 1.7% Retail Fans. RetailLights 2.8% Retail Cool 11.5% Carbon Intensity Square Footage Energy Intensity RetailEquip 3.6% Retail Signage Space Type SF % (kBtu/SF/year) (lbs/SF/year) 10.4% 0.8% **Retail Tenants** 88.151 11% 128.7 21.1 Office Tenants 718,266 89% 17.4 2.9 Space Heating 806.417 8.82 1.04 FMPIRE

REALTY TRUST

111 W 33rd Street Case Study

Baseline Energy Modeling

ECM Phasing and Packaging

Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



ECM Packages - Recommended Package is CO2 Mid

Four packages of ECMs were developed to optimize NPV and CO₂ reductions



Carbon Reduction

ECM Phases & Implementation Timeline: CO2 Mid

| | ENERGY CONSERVATION MEASURES (ECMS) | | | | IMPLEMENTATION TIMELINE | | | | | | | | | | |
|---------|-------------------------------------|---|------|------|-------------------------|------|------|------|------|------|------|------|------|------|------|
| Phase | Тад | Short Name | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Phase 1 | CO001 | BMS Integration & ASHRAE Guideline 36 | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |
| Phase 1 | CW002 | Retrocommission Tenant Condenser Water Economizer | 100% | 100% | | | | | | | | | | | |
| Phase 1 | CW005 | Pumping Optimization | 100% | 100% | | | | | | | | | | | |
| Phase 1 | CO003 | Chiller Plant Optimization | 100% | 100% | | | | | | | | | | | |
| Phase 1 | EN001 | Hoistway Smoke Vent Closure | 100% | 100% | | | | | | | | | | | |
| Phase 1 | LT003 | Reduce Retail LPD | 100% | 100% | | | | | | | | | | | |
| Phase 1 | LT002 | Reduce Retail Lighting Levels Overnight | 100% | 100% | | | | | | | | | | | |
| Phase 2 | EN002 | Mitigate Lobby Infiltration | 0% | 100% | | | | | | | | | | | |
| Phase 2 | AS002 | ERVs at AHUs | 0% | 100% | | | | | | | | | | | |
| Phase 3 | EL001 | Partial Heating Electrification: Air-to-Water Heat Pumps on 18th Floor + Steam Improvements & Condensate Recovery | 0% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | | | | | |
| Phase 4 | CO002 | Induction Unit Control Valves | 14% | 29% | 43% | 57% | 71% | 86% | 100% | 100% | | | | | |
| Phase 4 | LT001 | Lighting Upgrades & Controls | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | 100% | | |
| Phase 4 | TL001 | Plug Load Controls | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | 100% | | |
| Phase 4 | TL002 | IT Cooling Improvements | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% | 100% | | |
| Phase 5 | EL005 | Photovoltaics on L18 & Roof | 0% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |

111 W 33rd Street Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



111 W 33rd St. ECM Package Comparison: Energy Baseline: 2019



111 W 33rd St. ECM Package Comparison: Energy Baseline: 2009



Projected CO2 Emissions: Static 2019 Grid Scenario



Projected CO2 Emissions: Projected Grid Scenario

LL97 long term limit is 1,129 tCO₂e/year. All packages but CO₂ Light would meet this threshold



Proposed CO2e Emissions per Package (Projected Grid Scenario)

Projected CO2 Emissions: <u>CLCPA</u> Grid Scenario

2035 LL97 Limit is 1,129 tCO₂e/year. All packages would meet this threshold.

Proposed CO2e Emissions per Package (CLCPA Grid Scenario)



Projected Annual Carbon Emissions - <u>LL97 Compliance</u>

Current 2019 baseline & all packages are below 2024 and 2030 LL97 emissions limits



Total CO2 Emissions vs. Year - LL97 Grid Scenario

Projected Annual Carbon Emissions - Static 2019 Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; CO₂ High and Max packages achieve 2030 LL97 compliance on time; CO₂ Mid complies by 2031



Total CO2 Emissions vs. Year - Static Grid Scenario

Projected Annual Carbon Emissions - Projected Grid Scenario

Only CO₂ Max package would meet 80% reduction from 2009 baseline by 2035; All packages achieve 2035 LL97 compliance



Total CO2 Emissions vs. Year - Projected Grid Scenario

Carbon Emissions Extended to 2040 - Projected Grid Scenario

CO2 Light package does not meet 80% reduction from 2009 baseline by 2040;

CO₂ Mid package meets **80% reduction** from 2009 baseline by **2038;** CO₂ High package meets **80% reduction** from 2009 baseline by **2037;** Projected fines for CO₂ Light, Mid, High & Max from 2035-2040¹: \$170,036 (Light), \$116,814 (Mid), \$100,906 (High), \$75,490 (Max)



Total CO2 Emissions vs. Year - Projected Grid Scenario

1. Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the Projected grid scenario
Projected Annual Carbon Emissions - CLCPA Grid Scenario

All packages would meet 80% reduction from 2009 baseline by 2035, but BAU does not; All packages & BAU would meet 2035 LL97 compliance



Total CO2 Emissions vs. Year - CLCPA Target Grid Scenario

Carbon Emissions Extended to 2040 - CLCPA Grid Scenario

Projected fines for CO₂ Light, Mid, High, & Max from 2035-2040¹: \$26,556 (Light)



Total CO2 Emissions vs. Year - CLCPA Target Grid Scenario

1. Projected fines for 2035-2040 are calculated using 2022 proposed emissions limits and Luthin's GHG coefficients for the CLCPA grid scenario

Percent Carbon Emissions Reductions - <u>All Grid Scenarios</u>

80x35 target based on reductions from 2009 baseline Reductions from 2019 baseline show impact of packages compared to current usage

STATIC GRID SCENARIO

| _ | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-----------------|-------------|
| CO2 MAX | -28.2% | -32.7% | - 60.7 % | -63.1% |
| CO2 HIGH | -24.4% | -28.0% | -58.6% | -60.6% |
| CO2 MID | -21.3% | -24.8% | -56.9% | -58.8% |
| CO2 LIGHT | -15.8% | -19.0% | -53.9% | -55.6% |

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; CO_2 High and Max packages achieve 2030 LL97 compliance on time; CO_2 Mid complies by 2031

PROJECTED GRID SCENARIO

| _ | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -63.9% | -65.6% | -80.2% | -81.2% |
| CO2 HIGH | -60.9% | -62.0% | -78.6% | -79.2% |
| CO2 MID | -58.7% | -59.6% | -77.4% | -77.9% |
| CO2 LIGHT | -52.0% | -52.7% | -73.7% | -74.1% |

Only CO₂ Max package would meet 80% reduction from 2009 baseline by 2035; All packages achieve 2035 LL97 compliance

CLCPA TARGET GRID SCENARIO

| | 2019 - 2030 | 2019 - 2035 | 2009 - 2030 | 2009 - 2035 |
|-----------|-------------|-------------|-------------|-------------|
| CO2 MAX | -72.7% | -79.0% | -85.1% | -88.5% |
| CO2 HIGH | -69.9% | -75.8% | -83.5% | -86.7% |
| CO2 MID | -67.9% | -73.8% | -82.4% | -85.6% |
| CO2 LIGHT | -61.0% | -66.4% | -78.6% | -81.6% |

All packages would meet 80% reduction from 2009 baseline by 2035, but BAU does not; All packages & BAU would meet 2035 LL97 compliance

147

111 W 33rd Street Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



NPV, CO₂ Reductions and Simple Payback for all Packages Net Present Value for 2023-2035; CO2 reduction based on CLCPA scenario

NPV vs. CO2 Reduction from 2023-2035 (CLCPA Target Grid Scenario)



NPV calculated with 6% real discount rate

Projected LL97 Fines From 2024-2034

No LL97 fines projected for the baseline for 2024-2029 or 2030-2034

| | LL97 Fines From 2024-2034 | | | | | | | | | | | | |
|-----------------------|---|---|--------------------------------------|---|---|---|--|--|--|--|--|--|--|
| | LL97 of | 2019 Emission | s Limits ¹ | 2022 Proposed Emissions Limits ² | | | | | | | | | |
| Packages | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | Fine Avoidance From 2024- 2034 | Total Fine From 2024- 2029 ³ | Total Fine From 2030- 2034 ⁴ | Fine Avoidance From 2024- 2034 | | | | | | | |
| BAU (2019 Baseline) | \$0 | \$0 | - | \$0 | \$0 | - | | | | | | | |
| CO ₂ Light | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | | | | | | | |
| CO2 Mid | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | | | | | | | |
| CO2 High | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | | | | | | | |
| CO2 Max | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | | | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2024-2029 are based on GHG coefficients provided in LL97 of 2019.

4. Fine calculations for 2030-2034 are based on additional GHG coefficients provided in the proposed rules for LL97 released Oct. 2022.

Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario

Fines projected for baseline and CO₂ Light under currently published LL97 limits, though all packages offset most if not all the fines;

Fines possible from 2035-2049 for baseline and all packages if 2022 emissions limits are approved, though CO₂ Mid, High & Max offset most of the potential fines.

| | | Projected LL97 Fines From 2035-2050 Based on Projected Grid Scenario | | | | | | | | | | | | |
|---------------------|---|---|---|---|--------------------------------------|---|--|--|--|--|--|--|--|--|
| Packages | LL97 of | 2019 Emissions | Limits ¹ | 2022 Proposed Emissions Limits ² | | | | | | | | | | |
| | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | | | | | |
| BAU (2019 Baseline) | \$532,738 | - | \$0 | \$1,852,494 | - | \$263,260 | | | | | | | | |
| CO2 Light | \$139,214 | \$393,524 | \$0 | \$1,254,261 | \$598,234 | \$228,522 | | | | | | | | |
| CO2 Mid | \$0 | \$532,738 | \$0 | \$707,764 | \$1,144,731 | \$173,275 | | | | | | | | |
| CO2 High | \$0 | \$532,738 | \$0 | \$560,761 | \$1,291,733 | \$159,079 | | | | | | | | |
| CO2 Max | \$0 | \$532,738 | \$0 | \$319,676 | \$1,532,819 | \$135,517 | | | | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

- 2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.
- 3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario

No fines projected for the baseline or packages under currently published LL97 limits.

Fines possible from 2035-2049 for baseline and CO₂ Light if 2022 emissions limits are approved; CO₂ Mid, High, & Max offset all the potential fines.

| | | Projected LL97 Fines From 2035-2050 Based on CLCPA Grid Scenario | | | | | | | | | | | | |
|-----------------------|---|---|---|---|---|---|--|--|--|--|--|--|--|--|
| | LL97 of | f 2019 Emissions | Limits ¹ | 2022 Pro | 2022 Proposed Emissions Limits ² | | | | | | | | | |
| Packages | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | Total Fine From 2035- 2049 ³ | Fine Avoidance From 2035- 2049 | Annual Fine From 2050 Onward ³ | | | | | | | | |
| BAU (2019 Baseline) | \$0 | - | \$0 | \$106,721 | - | \$122,431 | | | | | | | | |
| CO ₂ Light | \$0 | \$0 | \$0 | \$63,308 | \$43,413 | \$118,851 | | | | | | | | |
| CO2 Mid | \$0 | \$0 | \$0 | \$0 | \$106,721 | \$60,092 | | | | | | | | |
| CO2 High | \$0 | \$0 | \$0 | \$0 | \$106,721 | \$48,866 | | | | | | | | |
| CO2 Max | \$0 | \$0 | \$0 | \$0 | \$106,721 | \$28,518 | | | | | | | | |

1. LL97 of 2019 emissions limits are calculated using the building emissions intensity limits provided in LL97 of 2019, which are based on occupancy group classifications, and the average building emissions limit expected to be enacted by 2050 (0.0014 tCO₂e/SF/yr).

2. 2022 proposed emissions limits are calculated using the building emissions factors provided in the proposed rules for LL97 released Oct. 2022, which are based on Energy Star property types.

3. Fine calculations for 2035-2049 and from 2050 onward are based on Luthin's GHG coefficients for the CLCPA grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.

Financial & Carbon Summary - Recommended Package is CO2 Mid

| Meets 80x35 Target (CLCPA Grid, Y/N) | CO2 Light (Y) | CO2 Mid (Y) | CO ₂ High (Y) | CO2 Max (Y) |
|---|--------------------------|---------------|--------------------------|----------------|
| Carbon Emissions in 2035 (CLCPA Grid) | 932 22% d | ecrease 728 | 673 | 583 |
| NPV (2023-2035) ¹ | \$1,071,139 | \$1,043,020 | (\$521,199) | (\$17,271,850) |
| NPV (Asset Life) ¹ | \$2,244,308 | \$2,765,979 | \$1,261,539 | (\$17,995,341) |
| Base Capital Cost ² | (\$3,015,512) | (\$4,515,512) | (\$4,515,512) | (\$5,798,355) |
| Incremental Capital Cost ² | (\$3,088,293) | (\$4,563,915) | (\$7,252,984) | (\$30,691,072) |
| Annual Energy Cost Savings ² | \$316,435 <u>50% i</u> i | \$474,641 | \$534,765 | \$648,425 |
| Annual Repairs & Maintenance Savings | \$650 | (\$1,750) | (\$4,750) | \$36,019 |
| Incentives | \$703,954 | \$987,484 | \$1,164,943 | \$1,500,503 |
| Simple Payback | 7.5 | 7.6 | 11.5 | 42.6 |

CO₂ Light Reduction - BMS integration & controls, CW & pumping optimizations, retail lighting improvements, tenant load improvements (lighting upgrades, plug load controls), electronic IU control valves

CO₂ Mid Reduction CO₂ Light + central plant optimization, infiltration mitigation, IT cooling improvements, ERVs, beneficial electrification via AWHPs on L18 & condensate recovery

CO2 High Reduction - CO2 Mid + TX ERV, entry vestibules, partial electrification of retail, & PVs on L18 & roof

CO2 Max Reduction - CO2 High + increased capacity AWHPs for full load heating of office, replacement of induction units with FCUs, AHU improvements, regenerative drives for elevators, PVs on setbacks only 153

Notes:

1. NPV calculated with 6% real discount rate

2. Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.



Financial Breakdown - Recommended Package is CO2 Mid

| | CO2 Light | CO2 Mid | CO2 High | CO2 Max |
|---|---------------|---------------|---------------|----------------|
| NPV (2023-2035) ¹ | \$1,071,139 | \$1,043,020 | (\$521,199) | (\$17,271,850) |
| NPV (Asset Life) ¹ | \$2,244,308 | \$2,765,979 | \$1,261,539 | (\$17,995,341) |
| Base Capital Cost ² | (\$3,015,512) | (\$4,515,512) | (\$4,515,512) | (\$5,798,355) |
| > Base Building Infrastructure | \$0 | (\$1,500,000) | (\$1,500,000) | (\$2,782,843) |
| > Tenant Fitout HVAC ³ | (\$3,015,512) | (\$3,015,512) | (\$3,015,512) | (\$3,015,512) |
| Incremental Capital Cost ² | (\$3,088,293) | (\$4,563,915) | (\$7,252,984) | (\$30,691,072) |
| Annual Energy Cost Savings ² | \$316,435 | \$474,641 | \$534,765 | \$648,425 |
| Annual Repairs & Maintenance Savings | \$650 | (\$1,750) | (\$4,750) | \$36,019 |
| Incentives | \$703,954 | \$987,484 | \$1,164,943 | \$1,500,503 |
| Simple Payback | 7.5 | 7.6 | 11.5 | 42.6 |

Notes:

1. NPV calculated with 6% real discount rate

 Base and incremental capital costs listed are based on current cost estimates and excludes future construction escalation costs. Annual energy cost savings listed are based on current 2022 estimates and exclude benefit from future utility cost escalations.

3. Tenant fitout HVAC base capital costs include cost of electronic induction unit control valves, code minimum plug load controls, and planned CapEx for LL88 lighting upgrades

154

EMPIRE STATE

Recommended Package - CO2 Mid

- Installation of 275-ton air-to-water heat pump (AWHP) capacity on level 18 setback partially electrifies space heating for office tenants in a cost-effective manner and provides redundancy for the central cooling plant
 - Provides low risk, cost-effective opportunity to test a heat pump installation with immediate benefit. Near term installation would benefit from opportunity to claim Clean Heat incentive from Con Ed (~10% of CapEx)
 - Existing chilled water piping system is converted operationally to a dual temperature changeover system to minimize new piping costs; in the winter AWHPs generate heating hot water to be used at existing AHU heating coils/perimeter induction loop
 - Installation of ~25% of the peak heating capacity provides over 75% of the available energy and carbon savings associated with electrification of the office tenant spaces
 - AWHP installation provides redundancy roughly equivalent to one of the SMARDT chiller compressors
- Although excluded from the recommended package to save on first costs, it is recommended that the retail tenants be engaged to consider the heating electrification retrofits in CO₂ High. These minimally disruptive alterations to existing retail systems in Target and Footlocker would partially electrify space heating by recovering heat from tenant condenser water loop saving cooling tower fan energy
 - Target has heat pumps installed already for cooling that can be utilized for heating as well in lieu of steam by reprogramming controls
 - Footlocker has chilled water FCUs with electric heating coils that can be strategically converted to heat pumps with economizer coils in exterior zones
- Photovoltaic installations on level 18 setback and roof should be explored further with a PV installer to further evaluate cost, financing options, incentives, and tax rebates available; PV installation may qualify for federal solar tax credits provided by the IRA

111 W 33rd Street Case Study

Baseline Energy Modeling ECM Phasing and Packaging Energy and Carbon Emissions Results Financial Analysis, LL97 Fines, and Recommendations Capital Expenditure and 2023 Budget



Annual Incremental Capital Cost per Package

Most of the capital expenditure occurs in the first 2 years to cover base building projects like controls optimizations, ERVs, and heating electrification (CO₂ Light - Max)



Year

Annual Incremental Capital Cost vs. Base Cost per Package

Base costs include planned replacement of steam chiller, induction unit control valve upgrades, planned LL88 lighting upgrades, code minimum plug load controls, & planned elevator modernization



111 W 33rd Street Next Steps - 2023 Projects

The recommended 2023 measures are focused on controls & lighting measures that have a combined payback of ~5.7 yrs & design of major 2024 projects

| Project | 2023 Total Incremental Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|--|-------------------------------------|--------------------------------|---------------------------------------|--------------------------|
| BMS Integration & ASHRAE Guideline 36 | \$1,011,255 | \$303,377 | \$707,879 | \$58,217 |
| Retrocommission Tenant Condenser Water Economizer | \$97,940 | \$28,697 | \$69,244 | \$9,946 |
| Pumping Optimization | \$87,283 | \$54,988 | \$32,295 | \$33,314 |
| Chiller Plant Optimization | \$167,818 | \$50,345 | \$117,472 | \$1,166 |
| Hoistway Smoke Vent Closure | \$12,922 | \$8,141 | \$4,781 | \$7,483 |
| Reduce Retail LPD | \$62,190 | \$0 | \$62,190 | \$25,435 |
| Reduce Retail Lighting Levels Overnight | \$9,061 | \$0 | \$9,061 | \$39,669 |
| Design of Heat Pumps, Condensate Recovery & ERVs | \$225,731 | NA | \$225,731 | NA |
| Total LL97 Budget | \$1,674,201 | \$445,547 | \$1,228,653 | \$175,230 |



Lessons Learned



Summary of Building Carbon Reduction Recommendations

OGCP

- Change out AC systems with VRF at every TI renovation up to floor 47 to stay on track with 2035 emissions targets without capex impact compared to replacements in kind
- Methodically address sources of air leakage in the building to reduce heating load, including building entrances.
- Change core bathroom water heating to electric as bathrooms are updated to eliminate summer steam usage.
- ▶ Leverage replacement of aging corridor chiller to provide efficient heating to floors 48-55
- Ensure that necessary elevator modernization isn't delayed; install regenerative drives

▶ 1400

- Transition away from water cooled systems to VRF. Upper floor condensing units can be roof mounted to preserve views. Lower floor condensing units can be located at windows with less desirable views.
- Heating electrification is key to meeting 2035 targets. Existing leases extending past 2035 will impede retrofit of significant portions of the building prior to 2035 meaning every available opportunity must be taken
- Immediately address uncontrolled heating at radiators and simultaneous heating and cooling through controls improvements.



Summary of Building Carbon Reduction Recommendations (Continued)

► 501

- Take advantage of available MER space to bring immediate reduction in cooling and heating consumption through ERV installations
- Install heat pumps to use waste heat in the condenser water system to heat floors 3 and 4 as spaces turn or at the time of consolidation into full floor or half floor leases.
- ► Coordinate disconnected tenant and landlord BMS to provide more energy efficient control

111 W 33rd Street

- Make targeted central plant and controls updates which take advantage of inherent efficiency of existing distribution design and MER space
- Installation of 275-ton air-to-water heat pump (AWHP) capacity on level 18 setback partially electrifies space heating for office tenants in a cost-effective manner and provides redundancy for the central cooling plant
- Consider engaging retail tenants to make targeted changes to the control of Target's heating systems and make a quick swap of a few of Foot Locker's AC units to achieve partial electrification and enable significant carbon emissions reductions.



Carbon Emissions Reductions Across the Portfolio

Overall carbon emissions reduction for the portfolio is $\underline{85.2\%}$ with the <u>CLCPA</u> grid and $\underline{79.1\%}$ with the <u>projected</u> grid

| Building | Recommended Package | Baseline Emissions (tCO2e) ¹ | 2035 Emissions - CLCPA Grid ² (tCO2e) | 2035 Emissions - Projected Grid ² (tCO2e) | Emissions Reduction - CLCPA Grid (%) | Emissions Reduction - Projected Grid (%) |
|-------------------------|------------------------|--|--|--|---|---|
| Empire State Building | CO2 Mid | 34,171 | 3,986 | 5,766 | 88.3% | 83.1% |
| 250 W 57th Street | CO2 Mid | 3,846 | 586 | 872 | 84.8% | 77.3% |
| 1350 Broadway | CO2 Mid | 2,173 | 484 | 682 | 77.7% | 68.6% |
| 1359 Broadway | CO2 Mid | 3,367 | 508 | 763 | 84.9% | 77.3% |
| 1333 Broadway | CO2 High-VRF | 2,282 | 413 | 594 | 81.9% | 74.0% |
| 111 W 33rd Street | CO2 Mid | 5,070 | 728 | 1,121 | 85.6% | 77.9% |
| One Grand Central Place | CO2 High | 6,474 | 1,232 | 1,627 | 81.0% | 74.9% |
| 501 7th Avenue | CO2 Mid | 3,039 | 732 | 956 | 75.9% | 68.6% |
| 1400 Broadway | CO2 High | 6,631 | 1,230 | 1,636 | 81.4% | 75.3% |
| | | 67,053 | 9,898 | 14,017 | 85.2% | 79.1% |

Notes:

1. Baseline emissions are based on 2007 utility bills and grid coefficients for the Empire State Building and 2009 utility bills and grid coefficients for all other buildings in the portfolio.

2. Projected emissions for 2035 are based on GHG coefficients published in LL97 for natural gas and steam, and Luthin's GHG coefficients for the CLCPA grid scenario and the Projected grid scenario, since GHG coefficients for the electrical grid have not yet been published by the City for these years.



Lessons Learned

- Planned CapEx provides an opportunity for improvements, do not replace in kind
 - When opportunities or needs arise to replace equipment, utilize the opportunity to promote carbon and energy efficiency with good ROI due to low incremental costs compared to replacement in kind.
 - ► OGCP VRF installation
 - OGCP AWHP installation/corridor chiller needs
 - ▶ 111 AWHP installation/chiller resiliency needs
 - Carbon and energy efficiency improvements will be strategically timed to optimize unit service life and meet carbon targets by 2035
 - Water-cooled AHUs at 501 7th Ave which are in good condition will be retained through their useful life
- Steam heating distribution is linked with higher carbon emissions across the portfolio
 - Steam heat: 250 W 57, OGCP, 1400 Broadway, 501 7th Ave, ESB
 - Hot water heat: 111 W 33, Westchester and Connecticut properties

- Tenant-installed water-cooled systems without modulating control prevent central systems from reducing flow at part load, wasting energy. Improved water flow control for these systems is an immediate opportunity for savings.
 - Examples include tenant systems in 1400 Broadway and the ESB retail loop
- Consistent rollout of high-performance standards is crucial
 - Key internal and external service providers (fit out designers, controls vendors, maintenance contractors, lease negotiators) require technical oversight to ensure all their work supports energy and carbon efficiency goals.
 - Small deviations of tenant designs from energy code and tenant design guidelines will delay achievement of carbon targets
 - Consider long-term ROI and operational consequences of first-cost decisions on all projects. Small decisions add up to big impact.



Energy Breakdown by Major End Users - All Buildings



Impact of Delays - OGCP as Example

| ENE | RGY CONS | SERVATION MEASURES (ECMS) | IMPLEMENTATION TIMELINE | | | | | | | | | | | | | | | | | |
|---------|----------|--|-------------------------|------|------|------|------|------|------|------|------|------|------|--------|----------|----------|---------|--------|-------|------|
| Phase | Tag | ECM Description | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 |
| Phase 1 | CO001 | BMS Integration of VAV Boxes & Radiator Valves & ASHRAE Guideline 36 | 33% | 67% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |
| Phase 1 | SS001 | Steam Cycle and Pressure Optimization | 100% | 100% | | | | | | | | | | | | | | | | |
| Phase 1 | EN005 | Hoistway Vent Closure | 100% | 100% | | | | | | | | | | | | | | | | |
| Phase 2 | CO005 | Control Valves & VFDs for Lobby AHUs | 0% | 100% | | | | | | | | | | | | | | | | |
| Phase 2 | EN008 | Fix Seals on the Revolving Doors | 0% | 100% | | | | | | | | | | | | | | | | |
| Phase 2 | EN004 | Freight Vestibule | 0% | 100% | | | | | | | | | | | | | | | | |
| Phase 2 | EN002 | Vestibule at Street | 0% | 100% | | | | | | | | | | | | | | | | |
| Phase 2 | DW002 | Conversion of Steam Domestic Hot Water Heating to Electric | 0% | 25% | 50% | 75% | 100% | | | | | | | | | | | | | |
| Phase 2 | UL001 | Replace DC Motors (Fans, Pumps) with AC | 0% | | | | 100% | | | | | | | Slower | r roll-o | ut of FC | Ms in t | enants | naces | |
| Phase 2 | VT001 | Regenerative Drives & Destination Dispatch for Elevators | 0% | | | | | | | 100% | 100% | | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |
| Phase 3 | EN001 | Radiant Barrier | 6% | 11% | 17% | 22% | 28% | 33% | 39% | 44% | 50% | 56% | 61% | 67% | 72% | 78% | 83% | 89% | 94% | 100% |
| Phase 3 | SS003 | Radiator Pipe Insulation | 6% | 11% | 17% | 22% | 28% | 33% | 39% | 44% | 50% | 56% | 61% | 67% | 72% | 78% | 83% | 89% | 94% | 100% |
| Phase 3 | TL002 | Lighting Upgrades & Controls | 6% | 11% | 17% | 22% | 28% | 33% | 39% | 44% | 50% | 56% | 61% | 67% | 72% | 78% | 83% | 89% | 94% | 100% |
| Phase 3 | TL001 | Plug Load Control | 6% | 11% | 17% | 22% | 28% | 33% | 39% | 44% | 50% | 56% | 61% | 67% | 72% | 78% | 83% | 89% | 94% | 100% |
| Phase 3 | EL001 | VRF Systems (ERV + DCV) for Office Tenants on Levels 3-47 | 6% | 11% | 17% | 22% | 28% | 33% | 39% | 44% | 50% | 56% | 61% | 67% | 72% | 78% | 83% | 89% | 94% | 100% |
| Phase 4 | EL004 | Replace Corridor Air-Cooled Chiller with AWHP Serving Levels 48-55 | 0% | 0% | 20% | 40% | 60% | 80% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |

Impact of Delays - OGCP Static 2019 Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2035 without grid decarbonization; No packages achieve 2030 LL97 compliance on time; CO₂ High and Max achieve limit by 2033 and 2032 respectively



Total CO2 Emissions vs. Year - Static Grid Scenario

Impact of Delays - OGCP Projected Grid Scenario

No packages would meet 80% reduction from 2009 baseline by 2035; Only CO₂ High and above packages meet 2035 LL97 limit



Impact of Delays - OGCP <u>CLCPA Grid</u> Scenario

No packages would meet 80% reduction from 2009 baseline by 2035; Only CO₂ Mid and above packages would meet 2035 LL97 limit



Appendix



Financial Model Assumptions Used for Discounted Cashflow Analysis

- Real discount rate: 6%
- Construction escalation rate: 3%
- Utility escalation rates used for analysis of buildings in 2022:

| | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
|-------------|------|------|------|-------|-------|-------|------|------|------|------|------|------|------|------|------|------|------|
| Electricity | 0.0% | 0.0% | 3.8% | 0.1% | 10.2% | 27.9% | 7.4% | 7.0% | 4.8% | 4.8% | 4.8% | 4.8% | 4.9% | 4.9% | 5.0% | 5.0% | 5.0% |
| Steam | 0.0% | 0.0% | 1.4% | 12.5% | 2.2% | -3.6% | 5.4% | 6.0% | 4.9% | 5.0% | 5.1% | 5.1% | 5.0% | 5.2% | 4.0% | 4.0% | 4.0% |
| Natural Gas | 0.0% | 0.0% | 1.4% | 2.8% | 42.5% | -9.7% | 0.4% | 2.9% | 3.4% | 5.3% | 5.3% | 5.3% | 5.3% | 5.3% | 5.3% | 5.3% | 5.3% |

Previous utility escalation rates used for analysis of buildings in 2021:

| | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
|-------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| Electricity | 0.0% | 0.0% | 3.8% | 5.2% | 3.7% | 9.4% | 5.1% | 5.1% | 5.0% | 5.0% | 5.0% | 5.0% | 4.6% | 4.6% | 4.8% | 4.8% | 4.9% |
| Steam | 0.0% | 0.0% | 1.4% | 2.8% | 2.2% | 2.4% | 2.8% | 3.4% | 2.2% | 2.3% | 2.5% | 2.5% | 2.3% | 2.5% | 1.4% | 1.4% | 1.4% |
| Natural Gas | 0.0% | 0.0% | 0.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% | 5.0% |

171

Utility Rates Based on Discounted Cashflow Analysis

Utility rates used for analysis of buildings in 2022

OGCP

| | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
|---------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Electricity (\$/kWh) | \$0.20 | \$0.21 | \$0.22 | \$0.22 | \$0.24 | \$0.31 | \$0.33 | \$0.36 | \$0.37 | \$0.39 | \$0.41 | \$0.43 | \$0.45 | \$0.47 | \$0.50 | \$0.52 | \$0.55 |
| Steam (\$/MLb) | \$33.94 | \$32.47 | \$34.12 | \$38.39 | \$39.25 | \$37.84 | \$39.90 | \$42.29 | \$44.35 | \$46.54 | \$48.90 | \$51.39 | \$53.95 | \$56.73 | \$59.00 | \$61.36 | \$63.81 |
| Natural Gas (\$/therm) | \$1.20 | \$1.20 | \$1.22 | \$1.25 | \$1.78 | \$1.61 | \$1.62 | \$1.66 | \$1.72 | \$1.81 | \$1.91 | \$2.01 | \$2.11 | \$2.23 | \$2.34 | \$2.47 | \$2.60 |

111 W 33rd St

| | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
|-------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Electricity (\$/kWh) | \$0.18 | \$0.19 | \$0.19 | \$0.19 | \$0.21 | \$0.27 | \$0.29 | \$0.31 | \$0.33 | \$0.34 | \$0.36 | \$0.38 | \$0.40 | \$0.41 | \$0.44 | \$0.46 | \$0.48 |
| Steam (\$/MLb) | \$49.56 | \$49.56 | \$50.25 | \$56.55 | \$57.81 | \$55.74 | \$58.77 | \$62.28 | \$65.31 | \$68.55 | \$72.02 | \$75.69 | \$79.45 | \$83.54 | \$86.89 | \$90.36 | \$93.98 |

172

Utility Rates Based on Discounted Cashflow Analysis

Utility rates used for analysis of buildings in 2022

501 7th Ave

| | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
|---------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Electricity (\$/kWh) | \$0.19 | \$0.19 | \$0.19 | \$0.19 | \$0.21 | \$0.27 | \$0.29 | \$0.31 | \$0.32 | \$0.34 | \$0.35 | \$0.37 | \$0.39 | \$0.41 | \$0.43 | \$0.45 | \$0.47 |
| Natural Gas (\$/therm) | \$1.20 | \$1.20 | \$1.22 | \$1.25 | \$1.78 | \$1.61 | \$1.62 | \$1.66 | \$1.72 | \$1.81 | \$1.91 | \$2.01 | \$2.11 | \$2.23 | \$2.34 | \$2.47 | \$2.60 |

1400 Broadway

| | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
|---------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Electricity (\$/kWh) | \$0.17 | \$0.17 | \$0.17 | \$0.17 | \$0.19 | \$0.24 | \$0.26 | \$0.27 | \$0.29 | \$0.30 | \$0.32 | \$0.33 | \$0.35 | \$0.36 | \$0.38 | \$0.40 | \$0.42 |
| Natural Gas (\$/therm) | \$1.20 | \$1.20 | \$1.22 | \$1.25 | \$1.78 | \$1.61 | \$1.62 | \$1.66 | \$1.72 | \$1.81 | \$1.91 | \$2.01 | \$2.11 | \$2.23 | \$2.34 | \$2.47 | \$2.60 |

Simple Payback Calculation Description

- Simple payback is calculated using:
 - Incremental capital cost associated with complete implementation of the ECM or package, based on 2022 cost estimates
 - Incentives available for complete implementation of the ECM or package, calculated using latest rates for programs from Con Edison and NYSERDA
 - Energy cost savings associated with complete implementation of the ECM or package, calculated using 2022 utility rates
 - Estimated annual impact to maintenance and repairs of systems

Incremental Capital Cost - Incentives

Simple Payback =

Annual Energy Cost Savings + Annual Maintenance Impacts



Empire State Building Next Steps - 2023 Projects

The recommended 2023 measures are focused on completing controls optimizations, EBC pilots and studies, chiller plant upgrades.

| Project | 2023 Total Project Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|---|---------------------------------|--------------------------------|---------------------------------------|--------------------------|
| HX for Cooling Plant Redundancy | \$445,967 | \$0 | \$445,967 | \$0 |
| Integration of Lighting with BMS - HVAC Scope | \$58,097 | \$0 | \$58,097 | \$0 |
| ERV Addition (Construction) | \$143,951 | \$218,976 | \$0 | \$218,976 |
| Electrification Phase 1 (Construction):Heating to AHUs (Combined w/ Steam Phase-Out Perimeter Systems) | \$7,101,080 | \$4,358,201 | \$2,742,879 | \$4,358,201 |
| Chiller Sequence of Operations (Design & Implementation) | \$450,000 | \$849,778 | \$0 | \$849,778 |
| Airside Sequence of Operations (Design & Implementation) | \$325,000 | \$353,851 | \$0 | \$353,851 |
| Domestic Water Pumps VFDs | \$465,791 | \$54,093 | \$411,698 | \$54,093 |
| Airside Retro-Commissioning (Continued) | \$175,000 | \$0 | \$175,000 | \$0 |
| Retail Condenser Water Pump Design Study | \$90,000 | \$289,578 | \$0 | \$289,578 |
| Domestic Hot Water Heat Pump (EBC Pilot) | \$132,417 | \$74,494 | \$57,923 | \$74,494 |
| Support ERV Pilots | \$25,000 | \$0 | \$25,000 | \$0 |
| Chiller Plant Upgrades - Low & Mid Zone | \$1,515,000 | \$0 | \$1,515,000 | \$0 |
| Chiller Plant Upgrades - High Zone | \$1,215,000 | \$0 | \$1,215,000 | \$0 |
| VAV Reheat Pilot | \$376,200 | \$0 | \$376,200 | \$0 |
| Electrification Phase 2: High Zone Heating Design | \$160,000 | \$0 | \$160,000 | \$0 |
| Total | \$12,678,503 | \$6,198,971 | \$7,182,764 | \$3,426,579 |



EMPIRE STAT

1350 Broadway Next Steps - 2023 Projects

The recommended 2023 measures are focused on infiltration mitigation, energy recovery ventilation, and low flow fixtures.

| Project | 2023 Total Project Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|---|---------------------------------|--------------------------------|---------------------------------------|--------------------------|
| Toilet Exhaust Energy Recovery Ventilator | \$544,706 | \$0 | \$544,706 | \$26,659 |
| Low flow fixtures | \$15,936 | \$0 | \$15,936 | \$4,641 |
| Mitigate Lobby Infiltration | \$11,589 | \$3,909 | \$7,680 | \$2,268 |
| Total | \$572,231 | \$3,909 | \$568,322 | \$33,569 |



1359 Broadway Next Steps - 2023 Projects

The recommended 2023 measures are focused on infiltration mitigation, demand control ventilation for retail, and electrification of domestic hot water for retail.

| Project | 2023 Total Incremental Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|--|-------------------------------------|--------------------------------|---------------------------------------|--------------------------|
| Demand Control Ventilation for Kitchen | \$117,054 | \$35,116 | \$81,938 | \$6,808 |
| Wolfgang's Domestic Water Heat Pump | \$257,287 | \$47,097 | \$210,189 | -\$1,307 |
| Mitigate Lobby Infiltration | \$28,394 | \$5,565 | \$22,829 | \$1,012 |
| Total | \$402,735 | \$87,778 | \$314,956 | \$6,513 |



250 W 57th Street Next Steps - 2023 Projects

The recommended 2023 measures are focused on lighting upgrades, infiltration mitigation, energy recovery ventilation, and installation of additional cooling capacity via heat pumps.

| Project | 2023 Total Incremental Cost (\$) | Anticipated Incentives (\$) | Total 2023 Cost w/ Incentives (\$) | Energy Cost Savings (\$) |
|--|-------------------------------------|--------------------------------|---------------------------------------|--------------------------|
| Electrification Phase 1: 300 Ton Heat Pump and Riser Construction | \$4,427,328 | \$647,474 | \$3,779,854 | \$44,132 |
| Toilet Exhaust Energy Recovery Ventilator | \$544,705 | \$127,808 | \$416,897 | \$16,486 |
| Mitigate Lobby Infiltration | \$11,590 | \$5,902 | \$5,688 | \$3,191 |
| Common Area Lighting Upgrades | \$6,780 | \$5,850 | \$930 | \$14,907 |
| Total | \$4,990,403 | \$731,647 | \$4,258,757 | \$78,716 |

